



Government Of West Bengal  
Office Of The Divisional Fire Officer, Hooghly  
West Bengal Fire & Emergency Services  
G.T. Road, Bose Para, Mahesh-1, Serampore,  
Hooghly, Pin :- 712202

Memo no.: IND/WB/FES/20182019/30706

Date: 19-04-2021

**From:**  
Divisional Fire Officer, Hooghly  
West Bengal Fire & Emergency Services

**To: SAKAMBARI PROCESSORS PVT. LTD.**  
VILL - DHALAR BAGAN, P.O - MAKALPUR , P.S- DADPUR, DIST- HOOGHLY

**Sub: Renewal of Fire Safety Certificate of an existing (G+1) storied Building along with Mezzanine floor Under Group of Industrial Building in the name & Style of 'SAKAMBARI PROCESSORS PVT. LTD.' at Vill – Dhalarbagan, P.O – Makalpur , P.S – Dadpur , Dist – Hooghly, Pin - 712302**

This is in reference to your application no. 0125191210200026 dated 23-03-2021 regarding the Renewal of Fire Safety Certificate of an existing (G+1) storied Building along with Mezzanine floor Under Group of Industrial Building in the name & Style of 'SAKAMBARI PROCESSORS PVT. LTD.' at Vill – Dhalarbagan, P.O – Makalpur , P.S – Dadpur , Dist – Hooghly, Pin - 712302

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

- 1.Regular checking, testing and maintenance of fire safety installation by a licensee.
- 2.Good house keeping to be maintained.
- 3.Regular checking and maintenance of electrical wiring and installation by a licensee Electricians.
- 4.Regular mock fire drill and evacuation drill should be conducted by participation of all and for this purpose a special crew should be formed.
- 5.Escape & entrance routes should not be obstructed if any way.
- 6.Open flame should not be left unattended.
- 7.Fire license to be obtained from this end for the premises (if any) which attracts sec - 12 of the Fire Service Act.

8.After 3 years a certificate shall have to be obtained from this office about the satisfactory performances of all the fire and life safety installations failing which is shall be revoked as per rule - 18 of the West Bengal Fire Services (Fire Prevention & Fire Safety) Rules - 2003.

Signature valid

Digitally signed by TAPAN  
KUMAR BOSE  
Date: 2021.04.09 15:51:58 IST

Divisional Fire Officer, Hooghly  
West Bengal Fire & Emergency Services