



Regional Director

संयुक्त सुरक्षित जल - सुरक्षित भविष्य
CONSERVE WATER - SAVE LIFE

भारत सरकार
केन्द्रीय भूमि जल अधिकरण
जल संसाधन विभाग

Government of India
Central Ground Water Authority
Ministry of Water Resources

CGWA/IND/Proj/1110-226

No. 21-4(389)/WR/CGWA/2009-2170

Dated: 08 AUG 2010

To,

M/s GRJ Distributors & Developers Pvt. Ltd.,
S - 5, Central Plaza
Golf Course Road
Gurgaon
Haryana

Sub:- NOC for ground water withdrawal by M/s GRJ Distributors & Developers Pvt. Ltd., in respect of their proposed Residential Township 'Avalon Garden (GRJ)', at village Khejriwas, Block & Tehsil Tijara, District Alwar, Rajasthan - reg.

Sh.


Kindly refer to your application dated 14.5.09 on the above cited subject. Based on recommendations of Regional Director, Central Ground Water Board, Western Region, Jaipur vide their office letter no. TS/21B(288)/CGWA/WR/2009-13 dated 18.05.10 and further deliberations on the subject, the NOC of Central Ground Water Authority is hereby accorded to M/s GRJ Distributors & Developers Pvt. Ltd., in respect of their proposed Residential Township 'Avalon Garden (GRJ)', at village Khejriwas, Block & Tehsil Tijara, District Alwar, Rajasthan. The NOC is however subject to the following conditions:-

1. The firm may abstract upto 182 m³/day of ground water, through proposed two (2) tube wells only. No additional ground water abstraction structures to be constructed for this purpose without prior approval of the CGWA.
2. Ground Water shall not be used for construction purpose at any point of time.
3. The wells to be fitted with water meter by the firm at its own cost and monitoring of ground water abstraction to be undertaken accordingly on regular basis, at least once in a month. The ground water quality to be monitored twice in a year during pre monsoon and post monsoon periods.
4. M/s GRJ Distributors & Developers Pvt. Ltd., shall, in consultation with the Regional Director, Central Ground Water Board, Western Region, Jaipur implement ground water recharge measures to the tune of 8573 m³/year, for

augmenting the ground water resources of the area. As the area is over-exploited additional recharge may be undertaken in nearby areas for augmenting the ground water resources.

5. The photographs of the recharge structures after completion of the same are to be furnished immediately to the Regional Director, Central Ground Water Board, Western Region, Jaipur for verification and under intimation to this office.
6. The firm at its own cost shall install piezometers at suitable locations and execute ground water regime monitoring programme in and around the project area on regular basis in consultation with the Central Ground Water Board, Western Region, Jaipur.
7. The ground water monitoring data in respect of S. No. 3 & 6 to be submitted to Central Ground Water Board, Western Region, Jaipur on regular basis at least once in a year.
8. The firm shall ensure proper recycling and reuse of waste water after adequate treatment.
9. Action taken report in respect of S. No. 3 to 8 may be submitted to CGWB within one year period.
10. The permission is liable to be cancelled in case of non-compliance of any of the conditions as mentioned in S. No. 1 to 9.


Yours faithfully /


24/5/10
Regional Director

Copy for information to:

1. The Member Secretary, State Level Environment Impact Assessment Authority, 4, Institutional Area, Jhalana Doongri, Jaipur 302004, Rajasthan. This has reference to your letter no. F1(4)SEIAA/SEAC_Raj/ Sect/ Project/ Cat(8aB1)(97)/09-09 dated 31.3.09.
2. The Regional Director, Central Ground Water Board, Western Region, Jaipur. This has reference to your letter no. TS/21B(288)/CGWB/WR/2009-13 dated 18.05.10.
3. TS to Chairman, Central Ground Water Board, Bhujal Bhawan, Faridabad.


24/5/10
Regional Director


24/5/10