

From

Commissioner
Municipal Corporation
Faridabad

To

M/s. Blue Sapphire Healthcares Pvt. Ltd.
Badkal Flyover Road, Sector - 21A,
Faridabad.

No.: ADFO/2017/F-223/811


Dated: 17/02/2017

Subject:

Renewal of fire NOC from the fire safety point of view of the Institutional Building namely known as Asian Institute of Medical Science for M/s. Blue Sapphire Healthcares Pvt. Ltd. at Badkal Flyover Road, Sector 21A, Faridabad.

Reference your letter no. NILL Dated 16.01.2017 on the subject cited above.

1. Your site for the Renewal of the Fire NOC has been inspected by the Team of Fire Station Officers, Faridabad from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the N.B.C. 1983 part IV revised 2015 guidelines.
2. In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-
 - a. The owner/occupier shall keep duly trained Fire Staff in all three shifts.
 - b. The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
 - c. If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
 - d. The open set back area is not checked at our end as it shall be checked by concerned building department.
 - e. The owner/occupier shall strictly follow the other applicable rules/regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per fire ordinance 2009 specially chapter- III Section 31 Sub-Section 1 & 2 of Fire Act 2009.
 - f. You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/R.W.A. should be mentioned in the drill.
 - g. If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the NOC as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
 - h. You are directed to apply for NOC in future before 1 month of expiry of your NOC with information enclosed Performa.
3. The owner/occupier of the building shall give a self declaration certificate annually to the effect that the fire fighting system installed in his building/premises is working in good condition and there is no addition/alteration in the building. In case there is any addition/alteration in the building, the Fire No objection Certificate shall cease to exist and the for approval of revised Fire Fighting Scheme as per Section 15 sub-section (1) of Haryana Fire Service Act (Amendment) 2016 and the competent authority may randomly check such building/premises.
4. This NOC is valid for only five year w.e.f. 09/02/2017 to 08/02/2022 as per Clause 19 of Fire Act 2009 Applying for renewal of the same well in time shall be the responsibility of owner/occupier.


Asst. Divisional Fire Officer
For Commissioner
MC Faridabad 17/02/17