



Uttar Pradesh Boiler Inspection Department
Certificate for Use of Boiler
(Regulation 389)

From:
Director of Boilers,
U.P. Kanpur

To,
The Boiler Owner,
Registry No: **UP-5388**

**M/S Govind Sugar Mills, Aira
Estate, Lakimpur Kheri.**

Date : 26.10.2021

You are allowed to work the above noted Boiler under the provisions of section 8 of THE BOILER ACT (V of 1923), at the maximum working pressure of 52* Kg/cm² from **26.10.2021** to **06.08.2022**.

*wp ltd to 45 kg/cm² at SHOH.

Remarks/Conditions:

1. Boiler to be worked by qualified Boiler Attendants/Boiler Operation Engineer only.

Director of Boilers,
U.P.
Kanpur

(See Reverse for Conditions)

Instructions to contain spread of COVID-19

1. Use of mask, gloves, helmet, shoes, goggles etc. is mandatory for boiler operation and maintenance staff.
2. Adequate arrangements shall be provided for temperature screening at Boiler premises.
3. Adequate facility for sanitizers/soap shall be made available at Boiler premises.
4. Social distancing to be ensured at boiler premises.
5. Use of Aarogya Setu App is mandatory for all staff working at Boiler premises.
6. Boiler premises shall be sanitized time to time.
7. There should be strict ban on chewing of gutka, tobacco etc. at Boiler premises, also spitting is strictly prohibited and punishable with fine as per government order.
8. Medical Insurance for all staff working at Boiler premises is mandatory.
9. All other instructions/advisories issued from time to time by Central/State Government to contain spread of COVID-19 shall be strictly followed.
10. Intensive communication and training on good hygiene practices shall be taken up.

CONDITIONS
(Reverse of Boiler Certificate)

(1) No structural alteration, addition or renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act.

(2) Under the provisions of Section 8 of the Act this certificate shall cease to be in force:

- (a) on the expiry of the period for which it was granted; or
- (b) when any accident occurs to the boiler; or
- (c) when the boiler is moved the boiler not being vertical boiler the heating surface of which is less than twenty square meter, or a portable or vehicular boiler; or
- (d) save as provided in section 12 of the Act, when any structural alteration, addition or renewal is made in or to the boiler; or
- (e) if the Chief Inspector in any particular case so directs when any structural alteration, addition or renewal is made in or to any steam-pipe attached to the boiler; or
- (f) on the communication to the owner of the boiler of an order of the Chief Inspector or Inspector prohibiting its use on the ground that it or any boiler component attached thereto is in a dangerous condition.

Under Section 10 of the Act, when the period of a certificate relating to a boiler has expired, the owner shall, provided that he has applied before the expiry of that period for a renewal of the certificate be entitled to use the boiler at the maximum pressure entered in the former certificate, pending the issue of orders on the application but this shall not be deemed to authorize the use of a boiler in any of the cases referred to in clauses (b), (c), (d), (e) and (f) of sub-section (1) of section 8 occurring after the expiry of the period of the certificate.

(3) The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the safety valve set to a pressure exceeding such maximum pressure.

(4) The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working.

(5) Feed & Boiler Water quality to be maintained as per Regulation 626.