

From

Date:04.03.2021

Wilson

Assistant Chief Engineering

Hilton Chennai

To

Rameshbabu Subramanian

Director of Finance

Hilton Chennai

Subject: Certification of Boiler License

Dear Sir,

Attached the original certificate Form VI of Boiler certification license of Boiler no: T-9048 & T-9049 from the Director of boilers

Boiler No: T-9048 Period from 25.02.2021 to 24.02.2022

Boiler No: T-9049 Period from 04.03.2021 to 03.03.2022

Kindly acknowledge the receipt of this original document

Regards,

A.Wilson



Received Original.
Hilal
4/3/21.
(with DOF).

No. 226A/SAC/2020-21 DIRECTORATE OF BOILERS, TAMIL NADU
CERTIFICATE FOR THE USE OF A BOILER
(Regulation 389)
FORM VI

Registry No. of Boiler. T-9048 Type of Boiler. HMT
Boiler Rating: 25m² Place and year of manufacture: Pune, 2009
Maximum continuous Evaporation: 1120 kg/hr
Name of Owner: Empel Hotels Limited,
Situation of Boiler: 124/152, Jawahar Lal Nehru Salai,
Ekkattuthangal, Chennai - 600 032.
Repairs: -
Remarks: -
Hydraulically tested on 25.02.2021 to 13.50 Kg/cm²

I, hereby certify that the above described boiler is permitted by me/the Director of Boilers under the provisions of Section 7/8 of The Boilers Act 1923 (Act V of 1923) to be worked at a maximum pressure of 10.55 Kg. per square C.M. for the period from 25.02.2021 to 24.02.2022.

The loading of the DSL safety valve is not to exceed 10.55 kg/cm²

I further certify that the main steam pipe was tested hydraulically to a pressure of 16.0 kg. per Square C.M. last on 18.03.2010

Fee Rs. 2100/- Paid on 21.01.2021

Dated at Ekkattuthangal

This 25th day of February 2021

4. [Signature]
25/02/2021
SENIOR ASSISTANT DIRECTOR OF BOILERS
SOUTH ARCOT CIRCLE
CUDDALORE - 607 001

Conutersigned
Director of Boilers.

No. 231/SAC/2020-21 DIRECTORATE OF BOILERS, TAMIL NADU
CERTIFICATE FOR THE USE OF A BOILER
(Regulation 389)
FORM VI

Registry No. of Boiler. T-9049 Type of Boiler. HTMT
Boiler Rating: 25 m² Place and year of manufacture: Pune, 2009
Maximum continuous Evaporation: 1120 kg/hr
Name of Owner: M/s. Empee Hotels Limited
Situation of Boiler: 124/1E2, Jawaharlal Nehru Salai,
Ekkattuthangal, Chennai - 600 032.
Repairs: -
Remarks: -
Hydraulically tested on 04.03.2021 to 13.50 Kg/cm²

I, hereby certify that the above described boiler is permitted by me/the Director of Boilers
under the provisions of Section 7/8 of The Boilers Act 1923 (Act V of 1923) to be worked
at a maximum pressure of 10.55 Kg. per square C.M. for the period
from 04.03.2021 to 03.03.2022

The loading of the DSL safety valve is not to
exceed 10.55 kg/cm²

I further certify that the main steam pipe was tested hydraulically to a pressure
of 16.0 kg. per Square C.M. last on 18.03.2010

Fee Rs. 2100/- Paid on 26.02.2021

Dated at Ekkattuthangal

This 04th day of March 2021

Y. K. Srinivasan
04/03/2021
SENIOR ASSISTANT DIRECTOR OF BOILERS
SOUTH ARCOT CIRCLE
CUDDALORE - 607 001

Conutersigned
Director of Boilers.