



SWIMMING POOL SANITARY CERTIFICATE

This is to certify that there is no sanitary objection to run a swimming pool at **EMPEE HOTELS LTD. T.S No.124, Jawaharlal Nehru Salai, Ekkattuthangal, Chennai-32** for the year **2020-21** subject to the following conditions.

1. Display board with rules and regulations governing the use of pool should be placed and it must contain the following information :
 - i) Persons suffering from skin diseases, sore eyes, cold, nasal or ear discharge or any other communicable diseases should not be allowed into the swimming pool.
 - ii) All bathers are strictly instructed to empty the bladder, and if necessary use the toilet.
 - iii) Spitting, spouting of water, blowing the nose, etc are prohibited.
2. The residual chlorine level should be maintained 1 ppm
3. The PH value of water to be kept between 7.4 and 7.8.
4. The bacteriological quality of water should be that of standards prescribed for drinking water.
5. Upto 15 percent of water should be replaced by fresh water every day.
6. The environment of the entire swimming pool premises should be kept neat and clean. The shower rooms, walkways and pool decks should receive proper disinfection to destroy bacterial, viral and fungal agents.
7. Life safety measures to be adopted round the clock in the pool.

V. Sankar
09/03/2021
Sanitary Inspector
Dn. 170

Sanitary Officer
Unit 40(A)

Sanitary Officer
09/03/2021
Zonal Health Officer
Zone XIII
Greater Chennai Corporation
ZONAL HEALTH OFFICER
ZONE 13
GREATER CHENNAI CORPORATION