

GOVERNMENT OF RAJASTHAN
FORM VI
Rajasthan State Boiler Inspection Department
CERTIFICATE FOR USE OF A BOILER
(Regulation 389)

Application Number :2021/30/BRenewal/21291

Registry Number of Boiler:MP-3461

Type of Boiler:WATER TUBE BOILER

Boiler Rating (m2):815

Place and year of manufacture:WALCHAND NAGAR, 1980

Maximum continuous Evaporation (kg/hr):14000

Name of Owner:M/S JK TYRE INDUSTRIES LTD

Situation of Boiler:PO TYRE FACTORY, JAYKAYGRAM, KANKROLI DISTT RAJSAMAND

Repairs: ---

Remarks: BOILER TO BE OPERATED BY VALID CERTIFICATE HOLDER FIRST CLASS BOILER
ATTENDANT ONLY

Hydraulically tested on 05/01/2022 to 25 kg/cm2


I hereby certify that the above described boiler is permitted by me / the Chief Inspector under the provisions of Section 7/8 of the Boilers Act No.V of 1923, to be worked at a Maximum pressure of 20.00 kg/cm2 for the period from 05/01/2022 to 25/12/2022

The loading of the spg. loaded safety valve is not to exceed max. working pressure allowed. I further certify that the main steam pipe was tested hydraulically to a pressure of last on

Fee: 7100 rs paid on 13/12/2021

Dated at: UDAIPUR(ONLINE)

Date : 07/01/2022


Competent Person
Pawan goyal , Dy. Chief
Inspector


Competent Person
Pawan goyal , Dy. Chief
Inspector

RJ 555
Boiler

GOVERNMENT OF RAJASTHAN
FORM VI
Rajasthan State Boiler Inspection Department
CERTIFICATE FOR USE OF A BOILER
(Regulation 389)

Application Number :2021/30/BRenewal/21093

Registry Number of Boiler:RJ-555

Type of Boiler:WATER TUBE

Boiler Rating (m2):1648.00

Place and year of manufacture:WEST BENGAL, 1983

Maximum continuous Evaporation (kg/hr):24.00

Name of Owner:M/S JK TYRE INDUSTRIES LTD

Situation of Boiler:JAYKAYGRAM, KANKROLI, DIST.:- RAJSAMAND

Repairs: ALL BANK TUBES NO. 108 REPLACED BY NEW IBR QUALITY MATERIAL BY M/S M.G.
ENGINEERS , KOTA, CAMP KANKROLI, WORK SATISFACTORY

Remarks: NA

Hydraulically tested on 03/12/2021 to 30.00 kg/cm2


I hereby certify that the above described boiler is permitted by me / the Chief Inspector under the provisions of Section 7/8 of the Boilers Act No.V of 1923, to be worked at a Maximum pressure of 24.00 kg/cm2 for the period from 03/12/2021 to 14/11/2022


The loading of the spg. loaded safety valve is not to exceed max. working pressure allowed. I further certify that the main steam pipe was tested hydraulically to a pressure of last on

Fee: 11900.00 paid on 30/10/2021

Dated at: CHITTORGARH

Date : 06/12/2021


Competent Person
Jankiram Gautam , Sr.
Inspector


Chief Inspector
Chief Inspector of Factories
and Boilers Rajasthan, Jaipur

This is a computer generated certificate and bears scanned signature. No physical signature is required on this certificate. You can verify this certificate by visiting www.rajfab.rajasthan.gov.in and entering Application No./ID after clicking the link for verification on the page.

RJ439

Boiler

GOVERNMENT OF RAJASTHAN
FORM VI
Rajasthan State Boiler Inspection Department
CERTIFICATE FOR USE OF A BOILER
(Regulation 389)

Application Number :2022/30/BRenewal/21754

Registry Number of Boiler:RJ-439

Type of Boiler:WATER TUBE BOILER

Boiler Rating (m2):597

Place and year of manufacture:YAMUNA NAGAR, 1976

Maximum continuous Evaporation (kg/hr):11000

Name of Owner:M/S JK TYRE INDUSTRIES LTD

Situation of Boiler:PO TYRE FACTORY, JAYKAYGRAM, KANKROLI, DISTT. RAJSAMAND (RAJO

Repairs: ----

Remarks: BOILER TO BE OPERATED BY VALID CERTIFICATE HOLDER FIRST CLASS BOILER ATTENDANTS ONLY

Hydraulically tested on 11/01/2022 to 22 kg/cm²


I hereby certify that the above described boiler is permitted by me / the Chief Inspector under the provisions of Section 7/8 of the Boilers Act No.V of 1923, to be worked at a Maximum pressure of 17.22 kg/cm² for the period from 11/03/2022 to 10/03/2023


The loading of the spg. loaded safety valve is not to exceed max. working pressure allowed. I further certify that the main steam pipe was tested hydraulically to a pressure of last on

Fee: 6600 RS. paid on 07/03/2022

Dated at: BANSWARA (ONLINE)

Date : 12/03/2022


Competent Person
Pawan goyal , Sr. Inspector


Chief Inspector
Chief Inspector of Factories
and Boilers Rajasthan, Jaipur

This is a computer generated certificate and bears scanned signature. No physical signature is required on this certificate. You can verify this certificate by visiting www.rajfab.rajasthan.gov.in and entering Application No./ID after clicking the link for verification on the page.

RJ438

Boiler

GOVERNMENT OF RAJASTHAN
FORM VI
Rajasthan State Boiler Inspection Department
CERTIFICATE FOR USE OF A BOILER
(Regulation 389)

Application Number :2022/30/BRenewal/21650

Registry Number of Boiler:RJ-438

Type of Boiler:WATER TUBE BOILER

Boiler Rating (m2):597

Place and year of manufacture:YAMUNA NAGAR, 1976

Maximum continuous Evaporation (kg/hr):11000

Name of Owner:M/S JK TYRE & INDUSTRIES LTD

Situation of Boiler:PO TYRE FACTORY, JAYKAYGRAM, KANKROLI, DISTT. RAJSAMAND (RAJ)

Repairs: ----

Remarks: BOILER TO BE OPERATED BY VALID CERTIFICATE HOLDER FIRST CLASS BOILER ATTENDANT ONLY

Hydraulically tested on 11/03/2022 to 22 kg/cm²


I hereby certify that the above described boiler is permitted by me / the Chief Inspector under the provisions of Section 7/8 of the Boilers Act No.V of 1923, to be worked at a Maximum pressure of 17.22 kg/cm² for the period from 11/03/2022 to 14/02/2023


The loading of the spg. loaded safety valve is not to exceed max. working pressure allowed. I further certify that the main steam pipe was tested hydraulically to a pressure of last on

Fee: 6600 rs. paid on 17/02/2022

Dated at: UDAIPUR(ONLINE)

Date : 12/03/2022


Competent Person
Pawan goyal , Dy. Chief
Inspector


Chief Inspector
Chief Inspector of Factories
and Boilers Rajasthan, Jaipur

This is a computer generated certificate and bears scanned signature. No physical signature is required on this certificate. You can verify this certificate by visiting www.rajfab.rajasthan.gov.in and entering Application No./ID after clicking the link for verification on the page.