



# GROUND WATER DEPARTMENT

(Namami Gange & Rural Water Supply Department)

Ministry of Jal Shakti

Government of Uttar Pradesh

## Form 8 (E)

[See rules 15(2)]

**(RENEWAL OF AUTHORIZATION/ NO-OBJECTION CERTIFICATE FOR SINKING OF EXISTING WELL FOR INDUSTRIAL/ COMMERCIAL/ INFRASTRUCTURAL OR BULK USER OF GROUND WATER)**

**AUTHORIZATION/ NO-OBJECTION CERTIFICATE NO:**

**VALID FROM --- TO ---**

<b>Registration No.: 202203000046</b>			
<b>Name of the Owner</b>	RAJ SINGH CHAUDHARY		
<b>Address of the Applicant</b>	BAJAJ HINDUSTHAN LIMITED UNIT -BHAISANA, TEHSIL- BUDHANA, DISTT- MUZAFFARNAGAR, UP	<b>Application Form Serial No.</b>	MZFN0322RIN0097
<b>Date of Submission</b>	04/03/2022	<b>Specimen Signature</b>	
<b>Company Name</b>	BAJAJ HINDUSTHAN SUGAR LTD UNIT BUDHANA	<b>Company Address</b>	Vill: Bhaisana, Teh: Budhana, Distt: Muzzafarnagar U.P
<b>NOC Issued By:</b> अनापत्ति प्रमाण पत्र (द्वारा निर्गत)			
<b>Central Ground Water Authority</b> केन्द्रीय भूगर्भ जल प्राधिकरण			Yes
<b>Certificate Number</b> प्रमाणपत्र संख्या	21-4/5139/UP/IND/2018	<b>Issue Date</b> निर्गमन तिथि	23/03/2018
<b>Expiry Date</b> अंतिम तिथि	21/02/2020		
<b>Ground Water Department Uttar Pradesh</b> भूगर्भ जल विभाग उत्तर प्रदेश सरकार			No
<b>Location Particulars</b>			
<b>District</b>	Muzaffar Nagar	<b>Block</b>	BUDHANA
<b>Plot No./Khasra No.</b>	Existing Land document attached.	<b>Municipality/Corporation</b>	No
<b>Ward No./Holding No.</b>			NA
<b>Particular of the Existing Well and Pumping Device</b>			
<b>Date of Construction/Sinking of the Well</b>	01/04/2005		
<b>Type of Well</b>	Tube Well/Boring	<b>Depth of the Well (In meter)</b>	143.00
<b>Purpose of well</b>	Industrial	<b>Assembly Size(For Tube Well)</b>	

<b>Strainer Position (For Tube Well)</b>			
<b>Type of Pump Used</b>	Submersible	<b>H.P. of the Pump</b>	45.00
<b>Operational Device</b>	Electric Motor	<b>Rate of Withdrawal (m<sup>3</sup>/hr.)</b>	155.00
<b>Date of Energization (In Case of Electric Pump)</b>		01/04/2005	
<b>Maximum Allowable Rate of Withdrawal (m<sup>3</sup>/hr.):</b>	155.00	<b>Maximum Allowable Running Hours Per Day:</b>	3.00
<b>Maximum Allowable Annual Extraction of Ground Water:</b>			55800.00
<b>Reason for renewal of N.O.C. एन.ओ.सी. के नवीनीकरण का कारण</b>	We have applied for NOC in CGWA on dated 22/3/2018. Further it is recommended from Regional office, CGWA Lucknow to Delhi. It is pending with NGT order and new guidelines.		
<b>Against Case</b>			
<p>This No-Objection certificate authorizes the owner applicant (user) to sink a well in the location specified at Sl. (3) for extraction of ground water at a rate not exceeding that as shown at Sl. (3j), for Running Hours per day as shown at Sl. (3k), and for maximum allowable annual extraction of ground water as shown at Sl. (3k) and is valid subject to the observance of the conditions stated overleaf.</p> <p>Place:</p> <p>Date:</p> <p style="text-align: right;">Yours Faithfully, Signature of the Issuing Authority and Designation</p>			
<b>Conditions</b>			
<ul style="list-style-type: none"> <li>(1) In case of any change of ownership of the proposed well, fresh authorization has to be obtained.</li> <li>(2) No change of location, design, rate of withdrawal and pumping device in respect of the proposed well as indicated at SL (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this authorization.</li> <li>(3) For the purpose of measuring and recording the quantity of ground water extracted, every said user shall affix digital water flow meters(conforming to BIS/ IS standards) having telemetry system in the abstraction structure, which record rate and quantum of extraction, at outlet of pumping devices and it shall be presumed that the quantity recorded by the meter has been extracted by the said user, until the contrary is proved. The rate of extraction of ground water from the well as shown in item 3(k) shall not exceed to the recorded rate from water meters</li> <li>(4) The concerned Authority reserves the right to stop extraction of ground water from the well due to quality hazards or any other reasons, if the situation so demands.</li> <li>(5) In case of any change of ownership of the existing well, fresh registration has to be obtained.</li> <li>(6) No change of location, design, rate of withdrawal and pumping device in respect of the existing well as indicated at Sl. (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this registration.</li> <li>(7) n case, any of the particulars I information furnished by the applicant in his application for issuance of this registration is found to be incorrect during verification at any subsequent stage, this registration is liable for cancellation.</li> <li>(8) The Certificate of Authorization/ NOC shall be valid for a period of five years from the date of issue. The applicant shall have to apply for renewal through a fresh application, at least ninety days prior to expiry of its validity.</li> <li>(9) Construction of piezometers and installation of digital water level recorders with telemetry shall be mandatory for user. Depth and zone tapped of piezometer should be commensurate with that of the pumping well. The data, obtained from digital water level recorders shall be made available to this office on monthly basis.</li> <li>(10) Guidelines for Installation of Piezometers and their Monitoring <ul style="list-style-type: none"> <li>Piezometer is a borewell /tube well used only for measuring the water level by lowering the tape/ sounder or automatic water level measuring equipment. It is also used to take water sample for water quality testing whenever needed. General guidelines for installation of piezometers are as follows for compliance of NOC: <ul style="list-style-type: none"> <li>The piezometer is to be installed/constructed at the minimum of 50 m distance from the pumping well through which ground water is being withdrawn. The diameter of the piezometer should be about 4" to 6".</li> <li>The depth of the piezometer should be same as is case of the pumping well from which ground water is being abstracted. If, more than one piezometer are installed the second piezometer should monitor the shallow ground water regime. It will facilitate shallow as well as deeper ground water aquifer monitoring.</li> <li>No. of piezometers to be constructed &amp; Type of water level monitoring mechanism shall be as per below table:</li> </ul> </li> </ul> </li> </ul>			

S.No	Quantum of Ground water withdrawal (cum/day)	No.of piezometers required	Monitoring Mechanism	
			Manual	DWLR with Telemetry
1	< 10	0	0	0
2	11 - 50	1	1	0
3	50- 500	1	0	1
4	> 500	2	0	2

- The measuring frequency should be monthly and accuracy of measurement should be up to cm. the reported measurement should be given in meter up to two decimals.
- For measurement of water level sounder or automatic water level recorder (AWLR)/ Digital Automatic water level recorder (DWLR) with telemetry system should be used for accuracy.
- The measurement of water level in piezometer should be taken, only after the pumping from the surrounding tube wells has been stopped for about four to six hours.
- All the details regarding coordinates, reduced level (with respect to mean level), depth, zone tapped and assembly lowered should be provided for bringing the piezometer into the Hydrograph Monitoring System for Ground Water Department, Uttar Pradesh, and for its validation.
- The ground water quality has to be monitored twice in a year during pre-monsoon (May/June) and post-monsoon (October/November) periods. Quality may be got analyzed from NABL approved lab. Besides, one sample (1 lt. capacity bottle) to the concerned Director, Ground Water Department, Uttar Pradesh, for chemical analysis.
- A Permanent display board should be installed at piezometer/Tube wells site for providing the location, piezometer/ tube well number, depth and zone tapped of piezometer/tube well for standard referencing and identification.
- Any other site-specific requirement regarding safety and access for measurement may be taken care of.
- (11) Any other condition(s) that may be imposed by the concerned Authority.
- (12) In case, any of the particulars / information furnished by the applicant in his application for issuance of this permit is found to be incorrect during verification at any subsequent stage, this permit is liable for cancellation.
- (13) Any other condition imposed by the concerned Authority
- **SPECIFIC CONDITIONS:**
- (A) **For Industrial User:** No Objection Certificate for ground water extraction by industries shall be granted subject to the following specific conditions:
  - i) No Objection Certificate shall be granted only in such cases where local government water supply agencies are not able to supply the desired quantity of water.
  - ii) All industries shall be required to adopt latest water efficient technologies so as to reduce dependence on ground water resources.
  - iii) All industries abstracting ground water in excess of 100 m<sup>3</sup>/d shall be required to undertake annual water audit through Confederation of Indian Industries (CII)/ Federation Indian Chamber of Commerce and Industry (FICCI)/ National Productivity Council (NPC) certified auditors and submit audit reports within three months of completion of the same to Ground Water Department, Uttar Pradesh. All such industries shall be required to reduce their ground water use by at least 20% over the next five years through appropriate means.
  - iv) Construction of observation well(s) (piezometer)(s) within the premises and installation of appropriate water level monitoring mechanism as mentioned in General Condition no.10 shall be mandatory for industries drawing/ proposing to draw more than 10 m<sup>3</sup>/day of ground water and. Monitoring of water level shall be done by the project proponent. The piezometer (observation well) shall be constructed at a minimum distance of 50 m from the bore well/production well. Depth and aquifer zone tapped in the piezometer shall be the same as that of the pumping well/ wells. Monthly water level data shall be submitted online to the Ground Water Department, UP.
  - v) The proponent shall be required to adopt roof top rain water harvesting/ recharge in the project premises. Industries which are likely to pollute ground water (chemical, pharmaceutical, dyes, pigments, paints, textiles, tannery, pesticides/ insecticides, fertilizers, slaughter house, explosives etc.) shall store the harvested rain water in surface storage tanks for use in the industry.
  - vi) Injection of treated/ untreated waste water into aquifer system is strictly prohibited.
  - vii) Industries which are likely to cause ground water pollution e.g. Tanning, Slaughter Houses, Dye, Chemical/ Petrochemical, Coal washeries, other hazardous units etc. (as per CPCB list) need to undertake necessary well head protection measures to ensure prevention of ground water pollution.
- (B) **Infrastructural User:** The No Objection Certificate for ground water abstraction will be granted subject to the following specific conditions:
  - i) In case of infrastructure projects that require dewatering, proponent shall be required to carry out regular monitoring of dewatering discharge rate (using a digital water flow meter) and submit the data online to Ground Water Department, UP as applicable. Monitoring records and results should be retained by the proponent for two years, for inspection or reporting as required by District Ground Water Management Council.
  - ii) Installation of Sewage Treatment Plants (STP) shall be mandatory for new projects, where ground water requirement is more than 20 m<sup>3</sup> /day. The water from STP shall be utilized for toilet flushing, car washing, gardening etc.

**This NOC is not authorized by any Official. This should only be used for Preview purpose.**  
**यह अनापत्ति प्रमाणपत्र किसी प्राधिकारी द्वारा प्रमाणित नहीं है। इसे मात्र पूर्वावलोकन के उद्देश्य से प्रयोग किया जाना चाहिए।**