

On Compliance *Rajesh*



Uttar Pradesh Boiler Inspection Department
Certificate for Use of Boiler
(Regulation 389)

From:
Deputy Director of Boilers
U P Kanpur

To,

The Boiler Owner

UP & UP
Registry No. 6594 6221

M/s

Bajaj Hindusthan Ltd

Budhana

M. Nagar

Date : 12-10-21

You are allowed to work the above noted Boiler under the provisions of section 8 of THE BOILER ACT (V of 1923), at the maximum working pressure of 53 kg/cm² from 12-10-21 to 21-08-22

WP limited to 45 kg at SHOH

Remarks/Conditions:

1. Boiler to be worked by qualified Boiler Attendant/Boiler Operation Engineer only

Dy Director of Boilers, U.P.

Kanpur

(See Reverse for Conditions)

Instructions to contain spread of COVID-19

1. Use of mask, gloves, helmet, shoes, goggles etc. is mandatory for boiler operation and maintenance staff.
2. Adequate arrangements shall be provided for temperature screening at Boiler entrance.
3. Adequate facility for sanitization/soap shall be made available at Boiler premises.
4. Social distancing to be observed at Boiler premises.
5. Use of AarogyaSetu App is mandatory for all staff working at Boiler premises.
6. Boiler premises shall be sanitized time to time.
7. There should be strict ban on chewing of gutka, tobacco etc. at Boiler premises, also eating is strictly prohibited and punishable with fine as per government order.
8. Valid Insurance for all staff working at Boiler premises is mandatory.
9. All other instructions/policies issued from time to time by Central/State Government to contain spread of COVID-19 shall be strictly followed.
10. No entry of any person in the premises who does not follow good hygiene practices shall be taken up.