

**GOVERNMENT OF ANDHRA PRADESH**  
**STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

**From :**

The Director General,  
State Disaster Response and Fire Services,  
Andhra Pradesh, Vijayawada.

**To :**

The General Manager,  
District Industries Center,  
East Godavari District.

.....  
**Rc.No.317/MSB/ER/EG/2015 MSB-ER, SDP Dated: 15-03-2022.**

Sir,

Sub: A.P. State Disaster Response and Fire Services Department-MSB Section-  
Issuance of Renewal of No Objection Certificate to Existing Building of M/s  
Nagarjuna Fertilizers and Chemicals Limited, Sy.No.279, 280, 282, 283,  
288, Nagarjuna Road, Kakinada, East Godavari District -Regarding.

- Ref: 1. Occupancy NOC.Rc.No.317/MSB/ER/EG/2015,Dated:07/11/2019 of  
Director General State Disaster Response and Fire Services,  
Andhra Pradesh, Vijayawada.  
2. Renewal NOC.Rc.No.14996/EG/MSB/2020,Dated:11/12/2020of  
Director State Disaster Response and Fire Services, Andhra Pradesh,  
Vijayawada.  
3. Application of M/s Nagarjuna Fertilizers and Chemicals Limited,  
Sy.No.279, 280, 282, 283, 288, Nagarjuna Road, Kakinada, East  
Godavari District.

\*\*\*\*\*

The Management of M/s Nagarjuna Fertilizers and Chemicals Limited,  
Sy.No.279, 280, 282, 283, 288, Nagarjuna Road, Kakinada, East Godavari District  
has requested to issue Renewal of No Objection Certificate by duly remitting the  
Renewal Fee towards Fire Precautionary Fee vide reference 3<sup>rd</sup> cited.

2) The No Objection Certificate for Occupancy Certificate was issued vide  
reference 1<sup>st</sup> cited to the existing Application of M/s Nagarjuna Fertilizers and  
Chemicals Limited, Sy.No.279, 280, 282, 283, 288, Nagarjuna Road, Kakinada,  
East Godavari District with (52) Blocks with total built up area of 76276.50 Sq.  
Mtrs., for Industrial Occupancy.

3) The management has submitted the self-Certification report and stated that  
the furnished information is correct and it is noticed at any time that the  
information provided is false, they understand that Renewal NOC deemed may be  
cancelled by the concerned authority.

4) In view of the above and taking into consideration of the larger public  
interest and in the context of the COVID-19 pandemic across the country and also  
based on the Self-Certification submitted by the management, the Renewal of No  
Objection Certificate is issued to the Existing Building of M/s Nagarjuna  
Fertilizers and Chemicals Limited, Sy.No.279, 280, 282, 283, 288, Nagarjuna Road,  
Kakinada, East Godavari District with (52) Blocks with total built up area of  
76276.50 Sq. Mtrs., for Industrial Occupancy.

5) It is suggested to the Management for providing the following Fire Safety Measures keeping in view of practicality, maintenance and resilience:

Sl. No.	Fire Fighting Equipment	Prescribed	Provided	Deficit
1	Fire Extinguishers	ABC type	312 Nos.	Nil
2	Temperature Sensors	Temperature Sensors connected "Hooter" and that can give alerts through Cell phone instead of Sprinklers	To be Provided	To be Provided
3	Manual Call Point System	One Number per Floor	50 Nos.	Nil
4	Under Ground Static Water Tank (or) Terrace Water Tank	5,000 Ltrs. (Minimum)	20,00,000 Ltrs.	Nil
5	5 HP (Mobile Pump + Petrol Engine on wheels connected to Ground Floor Sump)	3 Nos.	3 Nos.	Nil.

6) **Electrical Safety System.**

(i) Miniature Circuit Breakers, MCB's.	:	Yes/Provided
(ii) No Overloading of Power Sockets.	:	Yes, ensured
(iii) 10 years old wiring to be changed specially wherever A/c is there ?	:	Yes, ensured
(iv) LED Lights in Closed Rooms, Corridors, Staircases connected to Inverter (Battery).	:	Yes, Connected
(v) Grounding/Earthing is provided	:	Yes/Provided
(vi) Lightning Conductor is provided	:	Yes/Provided
(vii) The above shall be certified by authorized Electrical Contractor/ Supervisor.	:	Yes/Certified


7) **Fire Safety Suggestions:**

Sl. No.	As Builder	As Occupant	As Security personnel
1.	All the Fire protection arrangements shall be maintained in good working condition at all time.	The Escape/Exit roots shall not be kept Locked/Blocked or Encroached.	All the occupants must be trained the correct method of operation of the Fire Fighting System installed.
2.	Any loss of life or property due to non-functioning of Fire Safety Measures and other Installations shall be the responsibility of the management.	All occupants shall be trained to operate the Fire Safety Equipment during Emergency.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
3.	Addition/Alteration, if any in the Building may be verified by Building Authority.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All Security Personnel shall be trained to operate the Fire Safety Equipment during Emergency.
4.	This Annual Periodical Renewal Fire Certificate is only from Fire Safety Point of View.	Raise the alarm If the fire cannot be controlled, Evacuate the area completely at once with nearest Safe Exit.	Attack the Fire using available Fire Equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing Doors and Windows.



8) This Renewal of No Objection Certificate is valid for a period of Five years from the date of issue of this letter to the Management M/s Nagarjuna Fertilizers and Chemicals Limited, Sy.No.279, 280, 282, 283, 288, Nagarjuna Road, Kakinada, East Godavari District subject to the compliance of above Fire and Electrical Safety Measures. The Owner/Occupier/Builder/Management concerned of the Building shall submit Self Declaration/Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department Dated:13-08-2021 & G.O.Ms.No.120, Home (Prisons & Fire Services) Department Dated:25.10.2021, two (02) months before expiry of this Renewal of No Objection Certificate.

Yours Sincerely,



Director General,  
State Disaster Response and Fire Services,  
Andhra Pradesh, Vijayawada.

Copy to the Management, M/s Nagarjuna Fertilizers and Chemicals Limited, Sy.No.279, 280, 282, 283, 288, Nagarjuna Road, Kakinada, East Godavari District.

Copy to District Fire Officer, East Godavari District.

Copy to Regional Fire Officer, Eastern Region, Vijayawada.

**Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.**