

GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NALGONDA DISTRICT

From
B. Harinatha Reddy, B.Tech, MBA,
District Fire Officer,
Nalgonda, Attached to District Fire Officer,
West Zone/ Ranga Reddy District

To
The Commissioner of Industries,
Government of Telangana,
Chirag Ali Lane,
Hyderabad.

Rc. No.1756/A1/DFO-RR/2015, Dt. 26-09-2015.

Sir,

Sub:- Telangana State Disaster Response & Fire Services Department - Central Region -
Ranga Reddy District - TS-Ipass-2015 - Provisional No Objection Certificate to M/
Bhagwati Products Ltd, Plot No. S-1, Raviryala (V), Maheshwaram (M), Ranga Reddy
District - Issued - Regarding.

- Ref:-
- 1 Lr.No. 12/2015/TS-iPASS/Bhagwathi/179, Dt:24-09-2015, of the Commissioner of Industries, Government of Telangana, Chirag Ali Lane, Hyderabad.
 - 2 Inspection report of the Station Fire Officer, Maheshwaram, Rc.No._24/SFO/2015, Dt: 26-09-2015.
 - 3 Rc.No.5140/B1/2002, Dt: 29-10-2012, of the Director General of State Disaster Response and Fire Services, A.P, Hyderabad.
 - 4 Rc.No.15009/MSB/CR/HYD/2012, Dt: 13-04-2015 of the Director General, Telangana State Disaster Response and Fire Services, Hyderabad.

@@@@

With reference to 2nd cited above, the and Station Fire Officer, Maheshwaram have inspected the open site of M/s Bhagwati Products Ltd, Plot No. S-1, Raviryala (V) Maheshwaram (M), Ranga Reddy District and submitted inspection report and recommended for Issue of Provisional NOC.

Therefore, **Provisional No Objection Certificate** is issued, to establish M/s. Bhagwati Products Ltd, Plot No. S-1, Raviryala (V), Maheshwaram (M), Ranga Reddy District subject to adoption of the following Fire precautionary and preventive measures in the above premises by the management without fail.

i) Open Spaces

Direction	Required as per NBC Part 3, 8.3.1 e	To be Provided	Deficit
East	4.5 Mtrs.	4.5 Mtrs.	Nil
West	4.5 Mtrs.	4.5 Mtrs.	Nil
North	4.5 Mtrs.	4.5 Mtrs.	Nil
South	4.5 Mtrs.	4.5 Mtrs.	Nil

ii) Means of Escape (In case of Upper floors other than Ground Floor)

Staircase	Required No. with Width (in Mtrs) as per NBC	To be Provided	Deficit
Internal	1 No. with 1.5 Mtrs	1.50 Mtrs	Nil
External	1 No. with 1.25 Mtrs	1.25 Mtrs	
TOTAL		2.75 Mtrs	

iii) Load per unit Exit Width

Sl. No	Floor	Built-up Area (Sq.M)	Occupant Load (as per Table 20 of NBC)	Means of Escape required (as per Table 21 of NBC in Mtrs) as doors	To be Provided (in Mtrs)	Deficit
1	Production Shed 1	7200	720	4.8 Mtrs width exit in the form of Door	Atleast 4.8 Mtrs width exit in the form of Door	Nil
2	Production Shed 2	7200	720	4.8 Mtrs width exit in the form of Door	Atleast 4.8 Mtrs width exit in the form of Door	Nil
3	Production Shed 3	7200	720	4.8 Mtrs width exit in the form of Door	Atleast 4.8 Mtrs width exit in the form of Door	Nil
4	Production Shed 4	7200	720	4.8 Mtrs width exit in the form of Door	Atleast 4.8 Mtrs width exit in the form of Door	Nil
5	Admin Block	1200	120	2 Mtrs width exit in the form of Door	Atleast 2 Mtrs width exit in the form of Door	Nil
6	Utilities	720	72	1 Mtrs width exit in the form of Door	Atleast 1 Mtrs width exit in the form of Door	Nil
7	Canteen	214.4	22	1 Mtrs width exit in the form of Door	Atleast 1 Mtrs width exit in the form of Door	Nil
Total		31746.62 Sq.Mtrs (including Toilets/ VCB/Meter, Security 2 Nos)				

iv) Over all Fire Fighting Equipments required as per Table 23, Part -4, NBC -2005

Sl.No	Required as per Table 23 Part -4 of NBC of India	Required	To be Provided	Deficit
1	Fire extinguishers	317 No's	317 No's	Nil
2	Hose Reel system	21 No	21 No	Nil
3	Wet Riser	05 Nos	05 Nos	Nil
4	Yard Hydrant	34 No	34 No	Nil
5	Manually Operated Electric Fire alarm system	10 No	10 No	Nil
6	Automatic Sprinkler system	1043 No's	1043 No's	Nil
7	Automatic Detection and Alarm System	70 No's	70 No's	Nil
8	Underground Sump	1,00,000 Ltrs	1,00,000 Ltrs	Nil
9	Terrace Tank	20,000 Ltrs	20,000 Ltrs	Nil
10	Fire Pumps	01 Electrical 2280 LPM Pump	01 Electrical 2280 LPM Pump	Nil
		01 Diesel 2280 LPM Pump	01 Diesel 2280 LPM Pump	Nil
		01 Jockey 180 LPM Pump	01 Jockey 180 LPM Pump	Nil
		01 Booster Pump 900 LPM	01 Booster Pump 900 LPM	Nil

3) The Applicant has remitted Rs. 40,000/- which will be transferred to the DDO account vide reference 1st cited

//3//

4) The Provisional No Objection Certificate is issued subject to the following conditions:

- i. All Fire Safety measures as advised above should be provided without fail.
- ii. No temporary structure such as tents or with thatched construction shall be allowed in the premises

5) The builder/Management may be informed of the following Rules and Regulations:-

a) As per clause 13.1 of part-II of the National Building Code of India :neither granting of the NOC nor the approval of the drawings and specifications, nor inspections made by the Authority during erection of the building shall in any way relieve the owner of such building from full responsibility for carrying out the work in accordance with the requirements of the National Building Code of India".

b) As per clause 9.3 of part-II of the National Building Code of India "the Licensed Architect/Engineer/Structural Engineer/Supervisor/Town Planner shall be responsible for supervision of the construction and for the completion certificates. In the event of violation of the provisions of the code he shall be liable to penalties as prescribed by the Authority including cancellation of the License".

6) The builder may be advised that the building/Sheds should not be occupied without obtaining No Objection Certificate for occupancy from this department about the satisfactory installation of above Fire Safety measures.

(B. Hanmatha Reddy)
District Fire Officer
Nalgonda

Attached to the
District Fire Officer
West Zone/ Ranga Reddy District

Copy submitted to the Regional Fire Officer, Central Region, Hyderabad.
Copy to the Station Fire Officer, Maheshwaram.