

FIRE CHECK (INDIA)

A HOUSE OF TOTAL FIRE PROTECTION

Regd. Office : 1/5, Mahendra Banerjee Road, Shivlake Aagha, P.O. & P.S. : Parnasree, Kolkata-700060

Head Office : P-45 (22/2 Old), New Alipore, Block-J, Kolkata - 700 053

☎ : 09007074577, Mobile : 09007026248 / 09433422791

Branch Office : Tata Kandra Main Road, Paul Complex, Gamharia, Jamshedpur, Jharkhand

Mobile : 9204558244 / 9204558240

E-mail : mahendra0301gupta@gmail.com • fire_check.india@yahoo.co.in, Website : www.firecheckindia.in

M/s. ANVIL CABLES PRIVATE LIMITED

IOC More Gamharia, Large Sector,

Adityapur Industrial Area, Kharsawan.

Dist.: Saraikella, Jharkhand-832108

Date **November-20-2021**

Fitness Certificate of Fire Extinguishers


This is to certify that we have supplied the following No. of New / Refill Fire Extinguishers To M/s. ANVIL CABLES PRIVATE LIMITED

of IOC More Gamharia, Large Sector,

..... Adityapur Industrial Area, Kharsawan,

..... Dist.: Saraikella, Jharkhand-832108... on Dated **November-20-2021**

1. Refill ABC Stored Pressure Powder Type Fire Extinguisher capacity 06 Kgs. each.
(Qty: 05 Nos.)
2. Refill Mechanical Foam (AFFF) Stored Pressure Type Fire Extinguisher capacity 09 Ltrs. each.
(Qty: 01 No.)
3. Refill Carbon-di-oxide (Co2) Type Fire Extinguisher capacity 4.5 Kgs. each.
(Qty: 01 No.)



Now it is confirmed that all the above fire Extinguishers are in good and working condition and its Chemicals :

◆ Pressure Type Valid upto **November-19-2022**

◆ Cartridge Type Valid upto **November-19-2022**

For **FIRE CHECK (INDIA)**

Sales & Service Dept.

