

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20192020/73583

DATE: 11/12/2019

From :

The Director

Fire Prevention Wing,

West Bengal Fire & Emergency Services.

To :

TIL LIMITED

**MOUZA & P.O.- CHANGUAL, P.S.- KHARAGPUR, PASCHIM MEDINIPUR, PIN 721301
Kharagpur F.S., Kharagpur Local,
Paschim Medinipur - 721301 .**

**Sub :Renewal of Fire Safety Certificate for factory shed for manufacturing unit of
Material handling & Road construction handling equipments comprising different
section along with G+II storied office building under group Industrial Building in the
Name & Style of M/S TIL Limited . Kharagpur Project at Mouza – Changual. P.S.-
Kharagpur Local, Dist.- Paschim Medinipur, West Bengal.**

This is in reference to your Application No. IND/WB/FES/20192020/73583,dated 11/12/2019,
regarding the Renewal of Fire Safety Certificate for factory shed for manufacturing unit of
Material handling & Road construction handling equipments comprising different section
along with G+II storied office building under group Industrial Building in the Name & Style of
M/S TIL Limited . Kharagpur Project at Mouza – Changual. P.S.- Kharagpur Local, Dist.-
Paschim Medinipur, West Bengal. .

The performance of the Fire Fighting System as incorporated in the buildings were tested at
random and found satisfactorily working condition. In view of the above this office is releasing
the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety
measures need to be incorporated / maintained.

1. a. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- b. Entrances / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
- c. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
- d. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- e. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- f. A fire control room including a closed circuit TV system shall have to be installed which observe all the floors of the building.
- g. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the Building.
- h. The employees and security staff shall be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
- i. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- j. Transformer and Switch Gears room shall be protected with CO2 or DCP Fire extinguishers confirming I.S. specifications.
- k. A crew of trained Firemen shall be maintained round the clock for fire safety of the building.
- l. First Aid fire fighting system shall be provided as per I.S. specifications.
- m. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
- n. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

o. Periodical flashing of water in the Hydrants Pipe lines shall be made to maintain the efficient working performance of above mentioned system.

p. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

q. This Renewal of Fire Safety Certificate is valid for **Three Years** and has to be renewed from the date of issue of this letter.

r. The Renewal of Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

**Director
West Bengal Fire & Emergency Services**

Signature valid

Digitally signed by RATAN
KUMAR HALDER
Date: 2019.12.11 17:50:52 IST