

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No F6/DFS/MS/Hotel/SZ/2020/ 152

Dated: 13/03/2020

FIRE SAFETY CERTIFICATE

Certified that M/s Hyatt Regency Hotel (Asian Hotel (North) Ltd.) at Bhikaji Cama Place, New Delhi-110066, comprised of Block-A (Two Basement, Ground+12 upper Floors), Block-B (Ground, Service Floor + Seven upper floors) and New Block-C Ballroom (Ground+ Lobby floor) was issued FSC by this department vide letter No. F.6/DFS/MS/Hotel/SZ/2017/359 dated 14/03/2017. The premise was re-inspected by the officers concerned of this department on 06/03/2020 in the presence of Mr. Suman Majumder (Vice President), Engineering and found that the said hotel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "**Group A-5 Hotel Building**" with effect from 13/03/2020 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Rules 2010.

Issued on 13/03/20 at New Delhi by


(Atul Garg)
Director
Tel.-011-23414000

Copy to: -

- ✓ 1. The Mr. Suman Majumder (Vice President), Engineering M/s Hyatt Regency Hotel (Asian Hotel (North) Ltd.) at Bhikaji Cama Place, New Delhi-110066.
2. The Joint Commissioner of Police (Lic.), 1st Floor, Police Station, Defence Colony, New Delhi.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This fire safety certificate may not be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the First schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."