

From

Director,
Haryana Fire Service, Haryana,
Chandigarh.

To

M/s Identity Buildtech Pvt Ltd.
153, Okhla Industrial Estate, Phase-III,
New Delhi.


Memo No. DFS/F.A./2014/ 16258
Dated: 31.03.2014

Sub : **Approval of fire Fighting scheme from fire safety point of view of the Group Housing colony measuring 11.70 acres (Licence No. 32 of 2012 dated 12.04.2012) in VIII. Tikampur Sector 103, Gurgaon of M/s Identity Buildtech Pvt. Ltd.**

Reference your letter CFC No. 23313143000014, dated 13.02.2014, on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Gurgaon. The Fire fighting scheme is found as per the N.B.C. 1983 Part IV revised 2005/ guidelines. Therefore, your proposed fire fighting scheme is hereby approved from the fire safety point of view with the following conditions:-


- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un-noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler above false ceiling & pendent sprinkler below false ceiling shall be installed in the building.


Fire Officer, HQ
for Director, Haryana Fire Service,
Chandigarh

Endst. No- DFS/F.A./2014/

Dated 31.03.2014

A copy is forwarded to the Sr. Fire Station Officer, Sector 29, Gurgaon with reference to his Memo No.590 Dated 12.03.2014 for information and necessary action.


Fire Officer, HQ
for Director, Haryana Fire Service,
Chandigarh



भारत सरकार

पर्यावरण एवं वन मंत्रालय

GOVERNMENT OF INDIA

MINISTRY OF ENVIRONMENT AND FORESTS

File No. 4-1259/2013-RO (NZ)



जहाँ है हरियाली
वही है खुशहाली !!

दूरभाष :

TELEPHONE No. : (0172) 2638061

Fax No. : (0172) 2638135

उत्तर क्षेत्रीय कार्यालय

ब्लॉक नं० 24-25,

सेक्टर-31 ए, चण्डीगढ़ 160030

Northern Regional Office

Block No. 24 & 25, Sector 31-A,

Dakshin Marg, Chandigarh-160 030

Dated: 31.10.2013

To,

M/s Identity Buildtech Pvt. Ltd.

110, Indra Prakash Building, 21 - Barakhambha Road,
New Delhi - 110001

Sub: Group Housing Colony 'Highland Park' in the Revenue Estate of Village Tikampur,
Sector - 103, Gurgaon, Haryana.

Ref: SEIAA Haryana's letter no. SEIAA/HR/2013/948 dated 15.10.2013.

Sir,

Your kind attention is drawn to the reference cited letter wherein environmental clearance has been accorded to the above mentioned project by the SEIAA, Haryana constituted by the Ministry of Environment and Forests, New Delhi, with certain environmental conditions for compliance. *Since this Northern Regional Office of the Ministry of Environment and Forests has to inspect the project site to assess the implementation status of all the environmental safeguards and to submit factual periodical reports to the Ministry for further necessary action, you are requested to submit the following information to this office on top priority:*

1.	Name(s) and address(es) of the Project-Incharge along with telephone, FAX, mobile numbers and e- mail address(es);
2.	Current status of component-wise construction details;
3.	Exact location of the project site;
4.	Current status of point-wise compliance of the stipulated environmental conditions/safeguards;
5.	The area of forest land to be diverted if any, for passage or other purposes in the leased area and status of approval by the Ministry of Environment and Forests under the Forest (Conservation) Act, 1980;
6.	A copy of 'Application Form' and subsequent information submitted to SEIAA, Haryana for seeking environmental clearance;
7.	A copy of DPR/EIA/EMP report, etc., submitted to the SEIAA, Haryana;
8.	A copy of advertisement given in newspapers about the environment clearance; and
9.	Duly filled up 'Data-sheet' (a copy can be downloaded from the website www.nrmoef.gov.in)

An early reply is requested.

Yours faithfully,

(Surendra Kumar)

Director(S)

Tel. No.0172- 2638994

E Mail: sk581@yahoo.com