

DAKSHIN HARYANA BIJLI VITRAN NIGAM
 (A Power Distribution & Retail Supply Utility, Govt. of Haryana)
 An ISO 9001: 2008 Compliant Utility, CIN: U99999HR-1999SG034165
 Chief Engineer/Commercial, DHBVN, Hisar,
 Regd. Office: Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)
 Phone No. 01662-223093, Fax No. 01662223163
 Website: dhbvn.org.in E-Mail: cecommercialdhbvn@gmail.com

To

SE/OP Circle,
 DHBVN, Gurugram-I.

Memo No. Ch-7/SE/C-SOL-462

Dated 13/10/2017

Subject:- Approval for sanction of ultimate load 3560KW or 3955 KVA as well as partial load 1MVA under HT/BS/DS category to M/s Emar MGF Land Ltd, Imperial Garden project, Dwarka express way, Sector-102, Gurugram, under SDO 'OP' New Palam Vihar S/Divn., DHBVN, Gurugram.

Please refer to SDO/OP New Palam Vihar S/Divn., DHBVN, Gurugram Memo No 1272/73 dated 25.08.2017 on the subject cited matter above.

Approval for sanction of ultimate load 3560KW or 3955 KVA as well as partial load 1MVA along with electrification plan on single point connection under HT/BS/DS category to M/s Emar MGF Land Ltd, Imperial Garden project, Dwarka express way, Sector-102, Gurugram, is hereby accorded, subject to compliance of the terms and conditions given as under:-

1. The proposed load 3560 KW or 3955 KVA to M/s Emar MGF Land Ltd, Imperial Garden project, Dwarka express way, Sector-102, Gurugram under HT/BS/DS category shall be fed on 33 KV level from proposed 220/33 KV S/Stn. Sec-107, Gurugram from proposed 33 KV switching station through proposed 33 KV independent feeder with D/Run U/G 3x300mm² XLPE cable, at the cost of the consumer. The partial load of 1 MVA shall be fed from 66 KV S/Stn. Daultabad through proposed 11KV Independent underground feeder with 3CX300 mm² XLPE cable, at the cost of the applicant, subject to augmentation of capacity of 66/11KV Power Transformer T-IV from 12.5/16MVA to 25/31.5 MVA.
2. The developer shall install 2x2000KVA, 33/0.433KV, and 1x1000KVA, 33-11/0.433KV, Oil type transformers and (Total capacity 5000KVA) to cater their ultimate load by considering maximum loading of 80% of the rating of each T/F.
3. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.

4. The developer shall switchover his connection from 11KV to 33KV voltage level as per provisions of Nigam's Sales Circular no D-19/2015 and on switchover from 11KV to 33KV, the 11KV system will become the property of DHBVN.
5. Guidelines given in Sales Instruction No. 21/2015 shall be complied with by the applicant.
6. Complaint centers shall be constructed by the applicant as per Nigam instructions No. P&D 9/2011.
7. The applicant shall either deposit ACD corresponding to ultimate load in cash in one go or in the shape of BG.
8. SE/OP, DHBVN Gurugram-I should personally ensure that the BG of electrical infrastructure including at 11/33 KV level is deposited by the applicant as per Nigam instructions and commensurate with the ultimate load, prior to release of load including partial load.
9. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.
10. The applicant will enter into tripartite agreement with HVPN and DHBVN, if required.
11. The applicant will deposit the share cost as per the instruction of DHBVN/HVPN, if required.
12. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
13. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
14. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
15. The applicant will submit documentary proof in support of ownership of land.
16. Non-judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
17. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
18. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
19. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular Issued as well as amended by the Nigam from time to time before release.

20. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
21. Protection scheme to be provided on independent feeder at the S/Stn end for obtaining supply at 33KV level be got approved from the M&P wing of both DHBVN & HVPN.
22. The tariff to be charged from the residents should in accordance with tariff schedule approved by HERC.
23. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
24. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.
25. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.
26. The applicant shall comply with the provision of Haryana Renewable Energy Department regarding installation of solar photovoltaic Power Plant applicable time to time.

This issues with the approval of Director/Project, DHBVN, Hisar at NP-04 of file no. SOL-462.


CE/Commercial,
DHBVN, Hisar

CC to:-

1. The SPS to Director/Projects, DHBVN, Hisar for kind information of Director/Projects, please.
2. CE/OP, DHBVN, Delhi for kind information, please.
3. CE/TS, HVPN, Hisar.
4. CE/Planning, HVPN, Panchkula.
5. SE/TS, HVPN, Gurugram.
6. SE/NCR Planning, HVPN, Gurugram.
7. XEN/OP City Division, DHBVN, Gurugram.
8. SDO/OP New Palam Vihar S/Divn., DHBVN, Gurugram.
9. M/s Emar MGF Land Ltd, Imperial Garden project, Dwarka express way, Sector-102, Gurugram.

