

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
526/19, Shivaji Nagar, Opp. S.D Public School (Khandsa Road),
Gurugram (e-mail: xenceiggn@gmail.com).**

To

M/s Krishna Ishizaki Auto Ltd.,
58th KM Stone, Delhi-Jaipur Highway,
Vill. Binola, Gurugram

Application No. 5652-3157

Dated: 25/01/2022

Memo No: H.T.I / 1975


Dated: 31/01/2022

Subject: Inspection of installation comprising of 1x390 KWp Solar Power System installed at Krishna Ishizaki Auto Ltd., Gurugram.

The subject cited installation was inspected by this department on 31.01.2022 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010 except following observation which should be attended under intimation to this office:-

1. Proper railing and safety rope be provided around the solar panels at roof.

Approval to energisation of the subject cited installations is hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Further it is also advised to take other statutory permission if required from any other authority. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.


Executive Engineer
Electrical Inspectorate, Haryana,
1st Floor, 526/19, Shivaji Nagar,
Opp. S.D Public School, Gurugram-I