



सत्यमेव जयते

भारत सरकार
GOVERNMENT OF INDIA
विद्युत मंत्रालय, केन्द्रीय विद्युत प्राधिकरण
MINISTRY OF POWER, CENTRAL ELECTRICITY AUTHORITY
क्षेत्रीय निरीक्षण संगठन
REGIONAL INSPECTORIAL ORGANISATION

No. RIO/ER/Approval/DVC-Mejia/2022-23/ 156

Dated: 30th May, 2022

Dy. Chief Engg. (E)
Renewable Energy & Energy Efficiency
DVC Towers, VIP Road
Kolkata -700054

Subject: Approval for energisation of 1036.16KWp SPV Roof Top Solar PV at DVC Mejia under Reg.43 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation 2010

Ref: i) Your application no. A/2021/08932 Dated: 03/12/2021
ii) Your application no. A/2021/08929 Dated: 03/12/2021
iii) Inspection Report: RIO/ER/Ins. Report/DVC-Mejia/2021/525 Dated:14/12/2021
iv) Your Compliance :DVC/RE&EE/Rooftop Solar/Compliance Report/2022-23/21 Dated: 24/05/2022

Whereas the inspection of 1036.16kWp SPV Roof Top Solar Power Plant at different location at DVC Mejia was carried out by the undersigned on 11/12/2021 and inspection report was issued vide letter at Ref.(iii). Now compliance of our observations have been received vide your letter at Ref.(iv).

Approval is hereby granted to energize 1036.16kWp SPV Roof Top Solar Power Plant at different location at DVC Mejia. The approval is subject to Consistent compliance of relevant provisions of CEA (Measures relating to Safety and Electric Supply) Regulations 2010 as amended till date.

Details Of Solar Plant

Sl. No.	Location	DC Capacity	Inverter Capacity
1	220KV Building	53.6kWp	50kW
2	Reservoir Switch House	87.1kWp	40KW, 50KW
3	WT Plant 1-3	114.57kWp	50KW, 60KW
4	DM Plant	107.2kWp	50kW, 60KW
5	CW Pump House 1-3	87.1kWp	40KW, 50KW
6	CW Pump House 5-6	60.3kWp	60KW
7	Central Store Office	90.45kWp	40KW, 50KW
8	400KV Switchyard	26.8kWp	25KW

9	CW Pump House 7-8	46.9kWp	50kW
10	DAV Public School	120.935kWp	60kW, 60kW
11	DAV Public School	60.3kWp	60KW
12	Central Store Office	127.3kWp	50KW, 80KW
13	MTPS Club & Auditorium	53.6kWp	50kW

The above installation shall be due for periodical inspection under Reg. 30 within two years from the date of issue of this approval.

20/10/12
 (S.R. Fudu)
 25/10/2012

Electrical Inspector
to The Government Of India

Copy To:

1. Chief Electrical Inspector(CEI), NRPC Building, 3rd Floor, Katwariasarai, New Delhi – 110016