



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Block IV, Floor III, Shastri Bhawan,
Chennai – 600 006



No. 43/41/04/2022-RIO(S)/2911-2912

Dated: 29.04.2022

To

The Authorized Signatory,
ICAR- National Research Centre on Meat,
Rajendra Nagar,
Hyderabad – 500 030

Approval for Electrical Installation
(Under Regulation 43,32)

Equipment: Installation of 117.92 Solar Power Plan (List Enclosed at Annexure – 1 Page)	
Location:	ICAR- National Research Centre on Meat, Rajendra Nagar, Hyderabad
Inspected by:	Deputy Director, RIO, CEA, Chennai on 25.04.2022
Reference: -	1. On-line application No: A/2022/09635 dated 17.04.2022 2. Our Inspection Report: 43/41/04/2022-RIO(S)/ 2883-2884 dated 28.04.2022 3. Your Compliance No. Nil dated 29.04.2022

With reference to the above, approval is hereby granted for energizing the electrical installation as given above. This approval is strictly subject to your full compliance with the relevant provisions of the CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) in every respect. The statement of energization particulars may please be forwarded to this office immediately after energization of the installation.

The next inspection of these equipment under regulation 30 shall be due after two years from the date of this approval.

Yours faithfully,

Srikanth

(M. Srikanth Reddy)

Deputy Director &

Electrical Inspector to the Govt. of India

उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्नै / Chennai-600 006.

Copy to: The Chief Engineer (CEI), CEA, New Delhi – 110 066


NATIONAL RESEARCH CENETR ON MEAT CHENGICHERLA HYDERABAD T.S		
EQUIPMENT LIST OF 117.92.KWp SOLAR POWER PLANT		
SL.No	Name of the Equipment	Details of the Equipment
1	Inverters -1	Make = Solis SL.No = 110BE2218090004 Cap = 80 KW
2	Inverters -2	Make = Solis SL.No = 110D72213010048 Cap = 40 KW
3	Solar PV Modules	Make = WAAREE Energies Limited Qty = (335 Watts x 352 Modules) = 117.92KWp

LOADS DETAILS

Solar Inverters = 1x80KW + 1x40KW

Solar PV Modules = 335 Watts x 352 = 117.92 KWp

For PAVAN ELECTRICALS

(Raghavendra,
Proprietor)Govt. Approved "A" Grade Electrical Contractor
No. A/5275 2-1359

पञ्चायत आधिकारी

Administrative Officer

राष्ट्रीय मांस अनुसंधान केन्द्र (भा.कृ.उ.प. १)
National Research Centre on Meat (ICAR)
प्लॉट नं १९, उपग्रह पोस्ट ऑफिस, चेंगिचिरला, हैदराबाद-५०० ११९.
P.B.No.19, Uppal P.O., Chengicherla, Hyderabad-500 119उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्नै / Chennai-600 006.