

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
House No. 836, Sector-04, Rohtak.**

To

Trauma Centre,
PBDSUHS, Rohtak
(Haryana)

Memo No : 23738

Dated : 01/12/2021

Subject : Inspection of new installation comprising of 1x40 KWP Solar Plant installed at Trauma Centre, PBDSUHS, Rohtak (Haryana)

Reference your online Application no. 20211125-3464-2213 on dated 25-11-2021 the subject noted above.

The subject cited installation was inspected by this department on dated **01/12/2021** and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Except following observations which should be attended under intimation to this office:-

1. All the electrical apparatus/panels/LA and structure on which modules are erected should be connected with two separate and distinct earth. Earth pits also be identified.
2. All panels, invertors etc. be marked for their identification.
3. LT cables be provided through trenches/cable tray and connected with double earthed.

Approval for energisation of the same is hereby accorded subject hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are advised to provide the sealed energy meter for checking the reading and intimate to this office.


**Assistant Engineer
Electrical Inspectorate, Haryana
Rohtak**

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
House No. 836, Sector-04, Rohtak.**

To

Estate Officer,
PGIMS PBDSUHS, Rohtak
(Haryana)

Memo No : 23739

Dated : 01/12/2021

Subject : Inspection of new installation comprising of 1x77 KWP Solar Plant installed at
Estate Officer, PGIMS PBDSUHS, Rohtak (Haryana)

Reference your online Application no. 20211125-9219-8285 on dated 25-11-2021 the subject noted above.

The subject cited installation was inspected by this department on dated **01/12/2021** and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Except following observations which should be attended under intimation to this office:-

1. All the electrical apparatus/panels/LA and structure on which modules are erected should be connected with two separate and distinct earth. Earth pits also be identified.
2. All panels, invertors etc. be marked for their identification.
3. LT cables be provided through trenches/cable tray and connected with double earthed.

Approval for energisation of the same is hereby accorded subject hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are advised to provide the sealed energy meter for checking the reading and intimate to this office.


**Assistant Engineer
Electrical Inspectorate, Haryana
Rohtak.**

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
House No. 836, Sector-04, Rohtak.**

To

Estate Officer PGI,
PBDSUHS, Rohtak,
(Haryana)

Memo No : 23741

Dated : 01/12/2021

Subject : Inspection of new installation comprising of 1x182 KWP Solar Plant installed at PGI, PBDSUHS, Rohtak, (Haryana).

Reference your online Application no. 20211125-5890 -1099 on dated 25/11/2021 the subject noted above.

The subject cited installation was inspected by this department on dated **01/12/2021** and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010 except following observations which should be attended under intimation to this office:-

1. All the electrical apparatus/panels/LA and structure on which modules are erected should be connected with two separate and distinct earth. Earth pits also be identified.
2. All panels, invertors etc. be marked for their identification.
3. Fencing be provided surrounding the roof.
4. LT cables be provided through trenches/cable tray and connected with double earthed.

Approval for energisation of the same is hereby accorded subject hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are advised to provide the sealed energy meter for checking the reading and intimate to this office.

For more information visit www.ceiharyana.in
Next inspection shall due in Dec-2022


**Assistant Engineer,
Electrical Inspectorate, Haryana
Rohtak.**

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
House No. 836, Sector-04, Rohtak.**

To

Estate Officer,
Girls Hostel, PBDSUHS,
Rohtak, (Haryana)

Memo No : 23742

Dated : 01/12/2021

Subject : Inspection of new installation comprising of 1x33 KWP Solar Plant installed at Estate Officer, Girls Hostel, PBDSUHS, Rohtak, (Haryana)

Reference your online Application no. 20211125-4490-0355 on dated 25-11-2021 the subject noted above.

The subject cited installation was inspected by this department and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Except following observations which should be attended under intimation to this office:-

1. All the electrical apparatus/panels/LA and structure on which modules are erected should be connected with two separate and distinct earth. Earth pits also be identified.
2. All panels, invertors etc. be marked for their identification.
3. LT cables be provided through trenches/cable tray and connected with double earthed.

Approval for energisation of the same is hereby accorded subject hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are advised to provide the sealed energy meter for checking the reading and intimate to this office.


**Assistant Engineer
Electrical Inspectorate, Haryana
Rohtak.**

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
House No. 836, Sector-04, Rohtak.**

To

Mother Child PGIMS,
PBDSUHS, Rohtak (Haryana)

Memo No : 23744

Dated : 01/12/2021

Subject : Inspection of new installation comprising of 1x100 KWP Solar Plant installed at Mother Child PGIMS PBDSUHS, Rohtak (Haryana)

Reference your online Application no. 20211125-6676-5842 on dated 25-11-2021 the subject noted above.

The subject cited installation was inspected by this department on dated **01/12/2021** and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Except following observations which should be attended under intimation to this office:-

1. All the electrical apparatus/panels/LA and structure on which modules are erected should be connected with two separate and distinct earth. Earth pits also be identified.
2. All panels, invertors etc. be marked for their identification.
3. LT cables be provided through trenches/cable tray and connected with double earthed.

Approval for energisation of the same is hereby accorded subject hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are advised to provide the sealed energy meter for checking the reading and intimate to this office.


Assistant Engineer
Electrical Inspectorate, Haryana,
Rohtak.

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
House No. 836, Sector-04, Rohtak.**

To

Registrar MDU,
PBDSUHS, Rohtak
(Haryana)

Memo No :

23745

Dated :

01/12/2021

Subject :

Inspection of new installation comprising of 1x20 KWP Solar Plant installed at
Registrar MDU, PBDSUHS, Rohtak (Haryana)

Reference your online Application no. 20211125-0267-3794 on dated 25-11-2021 the subject noted above.

The subject cited installation was inspected by this department on dated **01/12/2021** and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Except following observations which should be attended under intimation to this office:-

1. All the electrical apparatus/panels/LA and structure on which modules are erected should be connected with two separate and distinct earth. Earth pits also be identified.
2. All panels, invertors etc. be marked for their identification.
3. LT cables be provided through trenches/cable tray and connected with double earthed.

Approval for energisation of the same is hereby accorded subject hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are advised to provide the sealed energy meter for checking the reading and intimate to this office.


Assistant Engineer
Electrical Inspectorate, Haryana
Rohtak

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana,
House No. 836, Sector-04, Rohtak.**

To

Boys Hostal,
PBDSUHS, Rohtak
(Haryana)

Memo No : 23746

Dated : 01/12/2021

Subject : Inspection of new installation comprising of 1x30 KWP Solar Plant installed at Boys Hostal, PBDSUHS, Rohtak (Haryana)

Reference your online Application no. 20211125-8540-9986 on dated 25-11-2021 the subject noted above.

The subject cited installation was inspected by this department on dated **01/12/2021** and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. Except following observations which should be attended under intimation to this office:-

1. All the electrical apparatus/panels/LA and structure on which modules are erected should be connected with two separate and distinct earth. Earth pits also be identified.
2. All panels, invertors etc. be marked for their identification.
3. LT cables be provided through trenches/cable tray and connected with double earthed.

Approval for energisation of the same is hereby accorded subject hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are advised to provide the sealed energy meter for checking the reading and intimate to this office.


**Assistant Engineer
Electrical Inspectorate, Haryana
Rohtak**