



**Government of India**  
**Central Electricity Authority**  
**Regional Inspectorial Organisation**  
**Block IV, Floor III, Shastri Bhawan,**  
**Chennai – 600 006**



No. 43/41/04/2022-RIO(S)/2913-2914

Dated: 29.04.2022

To

*The Authorized Signatory,*  
*ICAR- India Institute of Rice Research,*  
*Rajendra Nagar,*  
*Hyderabad – 500 030*

**Approval for Electrical Installation**  
**(Under Regulation 43,32)**

<b>Equipment:</b> Installation of 91.12 kWp Solar Power Plant (List Enclosed at Annexure – 1 Page)	
<b>Location:</b>	ICAR- India Institute of Rice Research, Rajendra Nagar, Hyderabad
<b>Inspected by:</b>	Deputy Director, RIO, CEA, Chennai on 25.04.2022
<b>Reference: -</b>	1. On-line application No: A/2022/09634 dated 17.04.2022 2. Our Inspection Report: 43/41/04/2022-RIO(S)/ 2883-2884 dated 28.04.2022 3. Your Compliance No. Nil dated 29.04.2022

With reference to the above, approval is hereby granted for energizing the electrical installation as given above. This approval is strictly subject to your full compliance with the relevant provisions of the CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) in every respect. The statement of energization particulars may please be forwarded to this office immediately after energization of the installation.

**The next inspection of these equipment under regulation 30 shall be due after two years from the date of this approval.**

Yours faithfully,

  
**(M. Srikanth Reddy)**  
**Deputy Director &**  
**Electrical Inspector to the Govt. of India**

उप निदेशक / Deputy Director  
क्षेत्रीय निरीक्षण संगठन  
Regional Inspectorial Organisation  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
चेन्नै / Chennai-600 006.

Copy to: The Chief Engineer (CEI), CEA, New Delhi – 110 066

*RICE*

INDIAN INSTITUTE OF <del>MILLETS</del> RESEARCH RAJENDRA NAGAR HYDERABAD T.S		
EQUIPMENT LIST OF 91.12.KWp SOLAR POWER PLANT		
SL.No	Name of the Equipment	Details of the Equipment
1	Inverters -1	Make = Solis SL.No = 110610218100018 Cap = 50 KW
2	Inverters -2	Make = Solis SL.No = 110D72213010043 Cap = 40 KW
3	Solar PV Modules	Make = WAAREE Energies Limited Qty = (335 Watts x 272 Modules) = 91.12KWp

LOADS DETAILSSolar Inverters = 1x50KW + 1x40KWSolar PV Modules = 335 Watts x 272 = 91.12 KWp

for PAVAN ELECTRICALS

*R. Ravandry*(Raghavendra,  
ProprietorGovt. Approved "A" Grade Electrical Contractor  
I. No. A/5275 2-1359*H. Jayaram*  
*प्रशासनिक अधिकारी*

Administrative Officer

भाकृअनुप-भारतीय चावल अनुसंधान संस्थान  
ICAR Indian Institute of Rice Research  
राजेन्द्रनगर, हैदराबाद-५०००३० (तेलंगाना)  
Rajendranagar, Hyderabad-500 030 (Telangana)*Srikanth*उप निदेशक / Deputy Director  
क्षेत्रीय निरीक्षण संगठन  
Regional Inspectional Organisation  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
चेन्नै / Chennai-600 006