

PVsyst - Simulation report

Grid-Connected System

Project: MATHURA DAS MATHUR HOSPITAL, JODHPUR-1000KW

Variant: New simulation variant

No 3D scene defined, no shadings

System power: 1356 kWp

Jodhpur - India

Author

Oriana power private limited (India)

**PVsyst V7.3.2**

VC0, Simulation date:
16/03/23 16:41
with v7.3.2

Project: MATHURA DAS MATHUR HOSPITAL,JODHPUR-1000KW

Variant: New simulation variant

Oriana power private limited (India)

Project summary

Geographical Site

Jodhpur

India

Situation

Latitude 26.27 °N

Longitude 73.01 °E

Altitude 245 m

Time zone UTC+5.5

Project settings

Albedo 0.20

Meteo data

Jodhpur

Meteonorm 8.1 (1996-2015) - Synthetic

System summary

Grid-Connected System

No 3D scene defined, no shadings

PV Field Orientation

Fixed plane

Tilt/Azimuth 20 / 40 °

Near Shadings

No Shadings

User's needs

Unlimited load (grid)

System information**PV Array**

Nb. of modules

4047 units

Pnom total

1356 kWp

Inverters

Nb. of units

10 units

Pnom total

1000 kWac

Pnom ratio

1.356

Results summary

Produced Energy 2285775 kWh/year Specific production 1686 kWh/kWp/year Perf. Ratio PR 83.39 %

Table of contents

Project and results summary	2
General parameters, PV Array Characteristics, System losses	3
Main results	4
Loss diagram	5
Predef. graphs	6
P50 - P90 evaluation	7
Single-line diagram	8



Project: MATHURA DAS MATHUR HOSPITAL,JODHPUR-1000KW

Variant: New simulation variant

PVsyst V7.3.2

VC0, Simulation date:
16/03/23 16:41
with v7.3.2

Oriana power private limited (India)

General parameters

Grid-Connected System

No 3D scene defined, no shadings

PV Field Orientation

Orientation

Fixed plane

Tilt/Azimuth 20 / 40 °

Sheds configuration

No 3D scene defined

Models used

Transposition Perez
Diffuse Perez, Meteonorm
Circumsolar separate

Horizon

Free Horizon

Near Shadings

No Shadings

User's needs

Unlimited load (grid)

PV Array Characteristics

PV module

Manufacturer

GOLDI SOLAR PVT LTD

Model

GOLDI072F335PY24

(Custom parameters definition)

Unit Nom. Power

335 Wp

Number of PV modules

4047 units

Nominal (STC)

1356 kWp

Modules

213 Strings x 19 In series

At operating cond. (50°C)

Pmpp

1236 kWp

U mpp

671 V

I mpp

1841 A

Total PV power

Nominal (STC)

1356 kWp

Total

4047 modules

Module area

8033 m²

Cell area

7343 m²

Inverter

Manufacturer

Sungrow

Model

SG110-CX

(Original PVsyst database)

Unit Nom. Power

100 kWac

Number of inverters

10 units

Total power

1000 kWac

Operating voltage

200-1000 V

Max. power (=>45°C)

110 kWac

Pnom ratio (DC:AC)

1.36

Power sharing within this inverter

Total inverter power

Total power

1000 kWac

Max. power

1100 kWac

Number of inverters

10 units

Pnom ratio

1.36

Array losses

Array Soiling Losses

Loss Fraction 2.0 %

Thermal Loss factor

Module temperature according to irradiance

Uc (const)

29.0 W/m²K

Uv (wind)

0.0 W/m²K/m/s

DC wiring losses

Global array res.

2.0 mΩ

Loss Fraction

0.5 % at STC

LID - Light Induced Degradation

Loss Fraction 1.7 %

Module Quality Loss

Loss Fraction -0.4 %

Module mismatch losses

Loss Fraction 0.1 % at MPP

Strings Mismatch loss

Loss Fraction 0.1 %

IAM loss factor

Incidence effect (IAM): User defined profile

0°	10°	20°	40°	50°	60°	70°	80°	90°
1.000	0.999	0.998	0.983	0.967	0.945	0.912	0.764	0.000

System losses

Unavailability of the system

Time fraction 0.1 %

0.4 days,

3 periods



Project: MATHURA DAS MATHUR HOSPITAL,JODHPUR-1000KW

Variant: New simulation variant

PVsyst V7.3.2

VC0, Simulation date:
16/03/23 16:41
with v7.3.2

Oriana power private limited (India)

Main results

System Production

Produced Energy

2285775 kWh/year


Specific production

1686 kWh/kWp/year


Performance Ratio PR

83.39 %

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor	DiffHor	T_Amb	GlobInc	GlobEff	EArray	E_Grid	PR
	kWh/m ²	kWh/m ²	°C	kWh/m ²	kWh/m ²	kWh	kWh	ratio
January	122.2	38.4	16.56	150.5	142.9	179457	177009	0.868
February	138.0	43.3	20.22	161.2	153.9	189835	187234	0.857
March	179.7	64.5	26.81	194.3	186.3	223199	220100	0.835
April	193.6	78.6	31.33	195.6	187.4	220841	217780	0.821
May	211.9	87.5	35.12	206.1	197.0	229586	222526	0.797
June	185.7	101.7	34.03	176.0	167.9	198516	195783	0.820
July	165.0	98.2	31.64	157.3	149.9	179759	177210	0.831
August	150.3	92.4	29.82	148.0	141.3	170673	168213	0.838
September	158.8	75.0	29.84	163.4	156.2	186959	184356	0.832
October	159.0	57.4	28.62	179.4	171.5	205166	198523	0.816
November	120.6	47.3	22.70	143.7	136.9	168249	165844	0.851
December	116.3	35.8	18.12	146.3	139.0	173698	171198	0.863
Year	1901.1	820.2	27.10	2021.8	1930.1	2325937	2285775	0.834

Legends

GlobHor Global horizontal irradiation

DiffHor Horizontal diffuse irradiation

T_Amb Ambient Temperature

GlobInc Global incident in coll. plane

GlobEff Effective Global, corr. for IAM and shadings

EArray Effective energy at the output of the array

E_Grid Energy injected into grid

PR Performance Ratio



Project: MATHURA DAS MATHUR
HOSPITAL,JODHPUR-1000KW


Variant: New simulation variant

PVsyst V7.3.2

VC0, Simulation date:
16/03/23 16:41
with v7.3.2

Oriana power private limited (India)

Loss diagram



Global horizontal irradiation

Global incident in coll. plane

IAM factor on global

Soiling loss factor

Effective irradiation on collectors

PV conversion

Array nominal energy (at STC effic.)

PV loss due to irradiance level

PV loss due to temperature

Module quality loss

LID - Light induced degradation

Mismatch loss, modules and strings

Ohmic wiring loss

Array virtual energy at MPP

Inverter Loss during operation (efficiency)

Inverter Loss over nominal inv. power

Inverter Loss due to max. input current

Inverter Loss over nominal inv. voltage

Inverter Loss due to power threshold

Inverter Loss due to voltage threshold

Night consumption

Available Energy at Inverter Output

System unavailability

Energy injected into grid



Project: MATHURA DAS MATHUR
HOSPITAL,JODHPUR-1000KW

Variant: New simulation variant


PVsyst V7.3.2

VC0, Simulation date:
16/03/23 16:41
with v7.3.2


Oriana power private limited (India)

Predef. graphs

Daily Input/Output diagram



System Output Power Distribution





Project: MATHURA DAS MATHUR HOSPITAL,JODHPUR-1000KW

Variant: New simulation variant

PVsyst V7.3.2

VC0, Simulation date:
16/03/23 16:41
with v7.3.2

Oriana power private limited (India)

P50 - P90 evaluation

Meteo data

Source Meteonorm 8.1 (1996-2015)
Kind Not defined
Year-to-year variability(Variance) -1.0 %

Specified Deviation

Global variability (meteo + system)

Variability (Quadratic sum) 2.1 %


Simulation and parameters uncertainties

PV module modelling/parameters 1.0 %
Inverter efficiency uncertainty 0.5 %
Soiling and mismatch uncertainties 1.0 %
Degradation uncertainty 1.0 %

Annual production probability

Variability 47 MWh
P50 2286 MWh
P90 2225 MWh
P75 2254 MWh

Probability distribution






PVsyst V7.3.2

VC0, Simulation date:
16/03/23 16:41
with v7.3.2

Single-line diagram



PV module	GOLDI072F335PY24
Inverter	SG110-CX
String	19 x GOLDI072F335PY24

MATHURA DAS MATHUR HOSPI
TAL,JODHPUR-1000KW

Oriana power priva
te limited (India)

VC0 : New simulation variant

16/03/23