



**U.P. Pollution Control Board**

**CONSENT ORDER**

**Ref No. -**  
**5207/UPPCB/Basti(UPPCBRO)/CTO/air/BALRAMPUR/2017**

**Dated : 08/02/2018**

**To ,**

M/S DR AJAY VIKRAM SINGH  
BAJAJ ENERGY LTD UTRAULA BALRAMPUR  
VILL ITAI MAIDA POST MAHUWA IBRAHIM DISTT BALRAMPUR UP  
BALRAMPUR

**Sub : Consent under section 21/22 of the Air (Prevention and control of Pollution) Act, 1981 (as amended) to M/s. BAJAJ ENERGY LTD UTRAULA BALRAMPUR**

Reference Application No. 234270

Dated : 08/02/2018

1. With reference to the application for consent for emission of air pollutants from the plant of M/s BAJAJ ENERGY LTD UTRAULA BALRAMPUR. under Air Act 1981. It is being authorised for said emissions, as per the standards, in environment, by the Board as per enclosed conditions .
2. This consent is valid for the period from 01/01/2018 to 31/12/2019 .
3. Inspite of the conditions and provisions mentioned in this consent order UP Pollution Control Board reserves its right and powers to reconsider/amend any or all conditions under section 21 (6) of the Air (Previntion and Controt of Pollution) Act, 1981 as amended.

This consent is being issued with the permission of competent authority .

**PRAMOD** Digitally signed by  
**MISHRA** PRAMOD MISHRA  
Date: 2018.02.20  
13:11:49 +05'30'

**For and on behalf of U.P. Pollution Control Board**

**Enclosed : As above**  
**(condition of consent):**

Copy to: Regional Officer, U.P. Pollution Control Board, Basti for information and necessary action.

**PRAMOD** Digitally signed by  
**MISHRA** PRAMOD MISHRA  
Date: 2018.02.20  
13:12:05 +05'30'

## U.P. Pollution Control Board

Dated : 08/02/2018

### CONDITIONS OF CONSENT

1. This consent is valid only for the approved production capacity of 90 Megawatt/hr Electricity .
- 2(a) . The maximum rate of emission of flue gas should not be more than the emission norms for the stacks.

Air Pollution Source Details					
S.No	Air Pollution Source	Type of Fuel	Stack No.	Parameters	Height
1	190 TPHx2 Boiler	Coal 1600 ton/day	1	Particulate Matter	110 mtr

- 2(b) . The emissions by various stacks into the environment should be as per the norms of the Board .

Emission Quality Details Detail			
S.No	Stack No	Parameter	Standard
1	1	Particulate Matter	150 mg/Nm3
2	1	Sulphur Dioxide	80 mg/Nm3
3	1	Oxides of Nitrogen	80 mg/Nm3

- 3 . Quantity of other pollutants should also be as per the norms prescribed by the Board/MOEF & CC/or otherwise mandatory .
- 4 . The equipment for air pollution control system and monitoring ,as proposed by the industry and approved by the Board should be installed in their premises itself .
- 5 . The modification or installation in the existing pollution control equipments should be done only by prior approval of Board .
- 6 . The operation of air pollution control system and maintenance be done in such a way that the quantity of pollutants should be in accordance with the standards prescribed by the Board/MoEF & CC/or otherwise mandatory .
- 7 . Unit should do provisions for fugitive emissions chimney/stack as per the norms of the Board/MOEF & CC/or otherwise mandatory .
- 8 . The unit should submit the stack emissions monitoring report within one month from issuance of consent order along with the point wise compliance report of the consent order . Further quarterly monitoring report should be submitted .

### Specific Conditions:

1. This consent is being issued only for production of 90 Megawatt/hr Electricity/power generation.
2. Industry shall submit Environment Statement to this Board as per provision of Environment (Protection) amendment Rule, 1993 for the previous year ending 31st March on or before 30th September every year.
3. Wide and dense green belt of broad leaf local species shall be developed all along the plant premises. As far as possible maximum area of open spaces shall be utilized for plantation purposes. Industry shall develop green belt within and around the plant premises in at-least 33% area of the total project area. Extensive tree plantation shall be carried out in this year.
4. Implementation report of Consent Compliance must be submitted.
5. The consent will be self-suspended in case of Closure issued by CPCB and incase of revoke closure order consent shall be effective for operation.
6. The industry have been maintain boundary-wall around the ash pond and insure for not leaching of effluent.
7. The industry shall be maintain the records of electricity consumption for the operation of APCS. and submit the mentioned details to UPPCB.
8. Stack and Ambient Air Monitoring report must be submitted every Three Months.
9. Industry shall make proper arrangement for safe and scientific handling, storage, transportation and disposal of coal Ash.
10. Industry have been comply to continues water sprinkling for control of fugitive dust emission.
11. All D.G. sets must have equipped with acoustic enclosure to control Noice Pollution.
12. Industry must be comply the order of CPCB as per charter.
13. Industry have been insure good house keeping in own campus and near by area.
14. Audited Balance Sheet/ C.A. Certificate should be submitted within one month from the date of issue of this Certificate for verification of Consent fee payable.

**Issued with the permission of competent authority .**

**PRAMOD** Digitally signed by  
**MISHRA** PRAMOD MISHRA  
Date: 2018.02.20  
13:12:19 +05'30'

**For and on behalf of U.P. Pollution Control Board .**