

Form VI
Boiler Inspection Department
Government Of Jharkhand
CERTIFICATE FOR USE OF A BOILER
 ([Regulation 389])

Application Number: BRR22032200024	Boiler Registry No.: JH/9192
Boiler Rating : 1424 meter square	Place and year of manufacture : Punjab (2019)
Maximum Continuous Evaporation 9.2 Tones per Hour	Manufacturer name : M/s Cheema Boiler Ltd.
Name of Owner: Jamuna Prasad Yadav	Boiler Maker No: CB-1880
Establishment name : NILACHAL IRON & POWER LTD.	Situation of Boiler Jamshedpur 2
Repairs(if any)	
Remarks Safety valves on drum rhs set pressure set at 75.8 and reset at 72.7 kg/cm2 with blowdown 4%. Safety valve on drum lhs set pressure 74.5 and reset pr. 71.0 kg/cm2 with b/d 4.5%. S/H O/L (MSSV) SET pressure 71.8 and reset pr. 68.9 with b/d 4.0 %. Boiler cut off at steam drum level by 20%. No. Of interlocks is 4 and No. Of instrument in line is 15.	
Type of Boiler : WHRB Boiler	
Hydraulically Tested on 30/03/2022	to 101 Kg per square cm

I hereby certify that the above described boiler is permitted by me/the Boiler Inspector under the provisions of Section 7/8 of the Indian Boilers Act, No. V of 1923, to be worked at a maximum pressure of **67 Kg per square cm** for the period from **30/03/2022 to 29/3/2023**

The loading of the safety valve is not to exceed **67 Kg per square cm**

Total Fee Paid (in INR) : **11100.0**

Note:

1. This is a computer generated certificate, does not require any seal.
2. This certificate has been generated on the basis of the information given by the applicant and is valid for the purpose of this act only.

Competent
Person /
Boiler
Inspector

Competent
Person /
Chief Boiler
Inspector



Form VI

**Boiler Inspection Department
Government Of Jharkhand
CERTIFICATE FOR USE OF A BOILER
([Regulation 389])**

Application Number: BRR22032200048	Boiler Registry No.: JH / 9178
Boiler Rating : 5120 meter square	Place and year of manufacture : Punjab (2019)
Maximum Continuous Evaporation 33 Tones per Hour	Manufacturer name : M/s Cheema Boiler Ltd.
Name of Owner: Jamuna Prasad Yadav	Boiler Maker No: CB-1882
Establishment name : NILACHAL IRON & POWER LTD.	Situation of Boiler Jamshedpur 2
Repairs(if any)	
Remarks Steam Drum Safety valves set at 76.3 kg/cm2 on lhs and 77.7 kg/cm2 on RHS and in super heater header 70.4 kg/cn2.	
Hydraulically Tested on 30/03/2022	to 101 Kg per square cm

I hereby certify that the above described boiler is permitted by me/the Boiler Inspector under the provisions of Section 7/8 of the Indian Boilers Act, No. V of 1923, to be worked at a maximum pressure of **67 Kg per square cm** for the period from **30/03/2022 to 29/3/2023**

The loading of the safety valve is not to exceed **67 Kg per square cm**

Total Fee Paid (in INR) : **24500.0**

Note:

1. This is a computer generated certificate, does not require any seal.
2. This certificate has been generated on the basis of the information given by the applicant and is valid for the purpose of this act only.

Competent
Person /
Boiler
Inspector

Competent
Person /
Chief Boiler
Inspector



Form VI

**Boiler Inspection Department
Government Of Jharkhand
CERTIFICATE FOR USE OF A BOILER
([Regulation 389])**

Application Number: BRR22032200030	Boiler Registry No.: JH/9196
Boiler Rating : 1424 meter square	Place and year of manufacture : Punjab (2019)
Maximum Continuous Evaporation 9.2 Tones per Hour	Manufacturer name : M/s Cheema Boiler Ltd.
Name of Owner: Jamuna Prasad Yadav	Boiler Maker No: CB-1881
Establishment name : NILACHAL IRON & POWER LTD.	Situation of Boiler Jamshedpur 2
Repairs(if any)	
Remarks Safety valves set at drum right hand side 75.8 and reset at 72.7 B/D 4% and drum left hand side 74.5 reset at 71.0 kg/cm² B/D 4.5% . On super heater header 71.8 reset pressure 68.9 B/D 4.0%.	Type of Boiler : WHRB Boiler
Hydraulically Tested on 30/03/2022	to 112 Kg per square cm

I hereby certify that the above described boiler is permitted by me/the Boiler Inspector under the provisions of Section 7/8 of the Indian Boilers Act, No. V of 1923, to be worked at a maximum pressure of **75 Kg per square cm** for the period from **30/03/2022 to 29/3/2023**

The loading of the safety valve is not to exceed **75 Kg per square cm**

Total Fee Paid (in INR) : **11100.0**

Note:

1. This is a computer generated certificate, does not require any seal.
2. This certificate has been generated on the basis of the information given by the applicant and is valid for the purpose of this act only.

Competent
Person /
Boiler
Inspector

Competent
Person /
Chief Boiler
Inspector