



FORM LS-1A/परूप - एनएस-1क

(See Rules 50, 51, 54 and 55)/नियम 50, 51, 54 और 55 देखें

Licence to Store Compressed gas in pressure vessel or vessels
दाब पात्र या पात्रों में संपीड़ित गैस भण्डारण के लिए अनुमति

फीस शुल्क/Fee Rs. 42500/- per year/वर्ष

अनुमति सं. Licence No. S/HO/WB/03/533(S100198)

Licence is hereby granted to NILKAMAL LIMITED, Plot No.2613, W.B.I.D.C. Industrial Complex, Mejia Roa, Kadasol, Kadasol, Taluka: Kadasol, District: BANKURA, State: West Bengal PIN: 722202 valid only for the storage of compressed gas in 2 Number(s) of pressure vessels as indicated below in the licensed premises described below and shown in the plan No.S/HO/WB/03/533 (S100198) dated 03/11/2022 subject to the provisions of the Indian Explosives Act, 1884 (4 of 1884) and the rules made thereunder and to the further conditions of this licence.

NILKAMAL LIMITED, Plot No.2613, W.B.I.D.C. Industrial Complex, Mejia Roa, Kadasol, Kadasol, Taluka: Kadasol, District: BANKURA, State: West Bengal PIN: 722202 को नीचे वर्णित अनुमति परिसरों में और रेखांकन संख्या S/HO/WB/03/533 (S100198) dated 03/11/2022 में भारतीय विस्फोटक अधिनियम, 1884 (का 4) और उसके अधीन बनाए गए नियमों तथा इस अनुमति की अन्य शर्तों पर 2 दाब पात्रों में संपीड़ित गैस के भण्डारण के लिए अनुमति मंजूर की जाती है।

यह अनुमति 30 सितंबर 2025 तक प्रवृत्त रहेगी।

The Licence shall remain in force till the 30th September 2025.

Vessel No./वैसल नंबर	Name of Gas/गैस का नाम	State of Gas/गैस की स्थिति	Water Capacity in cubic meter/जल क्षमता (घ.मी.)	Max. working Pre. (kg/cm ²)/अधिकतम वर्किंग प्रेशर	Quantity Granted in kgs/Liquidified gas/किलोग्राम में जारी मात्रा (लिक्विफाइड गैस)
M-PV-597	LPG	Liquidified	9.99	14.5	4700
M-PV-598	LPG	Liquidified	9.99	14.5	4700
Total Water capacity			19.99		

November 3, 2022

For Chief Controller of Explosives:

HO Nagpur

कृते मुख्य विस्फोटक नियंत्रक
नागपुर

DESCRIPTION AND LOCATION OF THE LICENSED PREMISES/अनुमति परिसर का विवरण और अवस्थिति

The licensed premises, the layout boundaries and other particulars of which are shown in the attached approved plan No. S/HO/WB/03/533 (S100198) dated 03/11/2022 are situated at Barjora, Kadasol and consists of 2 Mounded Number(s) vessel(s) for storage of compressed gas in 2 Number(s) of pressure vessels as indicated below in the licensed premises described below and shown in the plan No.S/HO/WB/03/533 (S100198) dated 03/11/2022 में दर्शाए गए हैं Barjora, Kadasol पर स्थित हैं और इसमें 2 Mounded वैसल सम्मिलित हैं।

Compressed/Corrosive/Toxic Gases /ज्वलनशील / सहायक / विषैली गैसें LPG

Compressed Gases /अविषैली गैसें

are situated at Plot No. 2613, J.L. No. 22, Village/Town: Barjora, Kadasol Police Station: Barjora, District: BANKURA, State: West Bengal Pin: 722202.

संख्या Plot No. 2613, J.L. No. 22 गांव या नगर: Barjora, Kadasol, पुलिस थाना: Barjora, जिला: BANKURA, राज्य: West Bengal, Pin: 722202 में स्थित

SPACE FOR ENDORSEMENT OF RENEWALS/नवीकरण के पृष्ठान्त के लिए स्थान

Date of Renewal/नवीकरण की तारीख	Date of Expiry/अनुमति की समाप्ति की तारीख	Signature and stamp of the licensing authority/अनुमति प्राधिकारी के हस्ताक्षर और कार्यालय की मुद्रा
This licence shall be renewable without any concession in fee for three years in the absence of contravention of the provision of the Indian Explosives Act 1884 or the Static and Mobile Pressure Vessels (Unfired) Rules 2016, framed thereunder or of the conditions of the licence /अनुमति, भारतीय विस्फोटक अधिनियम 1884 या उसके अधीन अधीन बनाए गए नियम एवं गतिशील दाब पात्र सम्बन्धित नियम 2016 या इस अनुमति की शर्तों का उल्लंघन न होने की दशा में, फीस में बिना किसी छूट के तीन वर्ष तक नवीकरणीय की जाएगी। Licence endorsed under Rule 49(4) of SMPV(U) Rules, 2016 after inspection on..... 26/11/2022 J.L. Chief Controller of Explosives East Circle, Kolkata		

The licence may be cancelled if the licensed premises are not found conforming to the description and conditions attached hereto and contravention of the provisions of the Indian Explosives Act 1884 and the rules made thereunder and the holder of the licence is also punishable with imprisonment for the term not exceeding three years or with fine which may extend to three thousand rupees or with both यदि निरीक्षण के समय अनुमति परिसर इसमें उपाखण्ड विवरण और शर्तों का उल्लंघन होता है तो उस दशा में यह अनुमति रद्द की जा सकती है और अनुमति का धारक कारावास से, जिसकी अवधि दो वर्ष तक की हो सकती है या जुर्माने से, जो तीन हजार रुपये तक का हो सकता है या

अनुमति रद्द की जा सकती है और अनुमति का धारक कारावास से, जिसकी अवधि दो वर्ष तक की हो सकती है या जुर्माने से, जो तीन हजार रुपये तक का हो सकता है या

Conditions of FORM 15-1A

Form No. 15 (H/O/W/03/53)(S100198)



- (a) Licensed premises shall conform to the description of location and facilities and to the approved plan as mentioned on the body of the licence.
- (b) Licensed premises shall have prominently marked thereon the number of the licence and for it.
- (c) Emergency telephone numbers of local fire service, police and the principal marketing company or supplier of the compressed gas, and conspicuous instructions shall be conspicuously displayed in the licensed premises.
- (d) The licensed premises shall not be used for any purpose other than the purpose for which the licence is granted.
- (e) The compressed gas shall be stored only in the vessels specified in the licence and shown in the approved plan attached hereto.
- (f) Storage vessel shall at all times maintain requisite safety distance from any other facility, building, boundary, fencing or protected works as specified in appropriate schedule specified in rule 22.
- (g) Suitable hard stand for parking of the vehicle during loading or unloading of any compressed gas shall be provided. The following minimum safety distances shall be maintained between the centre of the hard stand and the storage vessel, or the point of installation, as well as between the loading or unloading points, and the nearest boundary line of installation as specified under item (i) of sub-rule 2 of Rule 22.
- (h) Pressure of the vessel shall be maintained in good operating condition.
- (i) Alteration of the position of the vessel and no replacement of the vessel shall be effected except with the previous sanction, in writing, of the licensing authority as stated in the rules.
- (j) Any vessel before being repaired or exhausted shall be made free of compressed gas and thoroughly cleaned in a safe manner. When a vessel is opened for cleaning or repair, no lamp of any description either ordinary or electric, electric cables or fans and no articles, appliances or equipment capable of igniting flammable vapours shall be brought near the vessel.
- (k) No person shall cause to repair or repair either by the use of fire, welding, hot riveting or brazing any vessel used for the storage of flammable gas unless it has been thoroughly cleaned and gas-freed or otherwise prepared for safely carrying out such work and certified in writing, by a competent person, to have been so prepared.
- (l) If the vessel has been certified as gas-free, the certificate shall be preserved by the licensee for a period of not less than three months and produced to the licensing authority on demand.
- (m) No person shall enter any vessel used for the storage of a toxic or corrosive gas unless he is adequately protected by means of protective clothing, gas masks and such other equipments as may be required in the specific case.
- (n) Compressed gas shall be filled into or removed from the vessel through designated pipes of required specification and through transfer facilities shown in the approved plan.
- (o) The vessel shall not be filled between the hours of sunset and sunrise, unless adequate lighting of approved type is provided and except in such manner and such other conditions or conditions as are specifically endorsed on the licence by the licensing authority.
- (p) All operations in the licensed premises shall be carried out by persons competent in such operation. Every person managing or employed on or in connection with the licensed premises shall abstain from any act whatsoever which tends to cause fire or explosion and which is not reasonably necessary and to the best of his ability, shall prevent any other person from doing such act.
- (q) The licensee shall provide for each licensed premises a minimum of two portable foam type or dry chemical type fire extinguishers of 9 kg. capacity each, which shall be kept ready at convenient location for immediate use in the event of any fire in addition to other fire fighting or other mitigating facilities required for flammable or toxic gases.
- (r) All valves in the premises must be permanently marked in a manner clearly indicating the direction of opening and shutting the valve.
- (s) Access to the licensed premises shall be given at all reasonable times to any of the officers specified in rule 22 and every facility shall be afforded to such officers for ascertaining that the rules and the conditions of this licence are duly observed.
- (t) If the licensing authority calls upon the holder of a licence by a notice in writing to execute any repairs in the licensed premises which are, in the opinion of such authority, necessary for the safety of the premises, the holder of the licence shall execute the repairs within such period as may be specified in the notice.
- (u) Every vessel shall be outside any building and shall be supported on well designed calculations.
- (v) No artificial light capable of igniting flammable vapour shall at any time be present within nine metres of the vehicle and the loading or unloading points during the transfer of the compressed gas and no person engaged in such transfer shall smoke.
- (w) All electrically equipment such as motors, switches, starters used for transfer of liquefied petroleum gas shall be of flameproof construction conforming to IS 1014 (Part 1) or IS 1014 (Part 2) or of a type approved by the Chief Controller.
- (x) Smoking, naked lights, lamps, source of fire or any other stimulant capable of igniting flammable vapours shall not be allowed inside the premises. Every person managing or employed on or in connection with licensed premises shall abstain from any act whatsoever which tends to cause fire or explosion and which is not reasonably necessary and to the best of his ability, shall prevent any other person from doing such act.
- (y) Any accident, fire, explosion or untoward incident occurred within the licensed premises shall be immediately reported to the Chief Controller of Explosives, Controller, nearest police station and District Magistrate by quickest mode of communication.

For The Chief Controller of Explosives, Nagpur (M.S.)

For NILKAMAL LIMITED

(Signature)
Manager (Factory)
(Panchdew Giri)