GOVERNMENT OF MAHARASHTRA

NO: 88 /FA

OFFICE OF THE FIRE ADVISOR

State Fire Academy, Hans Bhugra Marg, Kalina Santacruz East, Mumbai-98

Date: 11/02/15

M/s. Nilkamal Limited Plot NO: 971A-1a At STICE, Musalgaon, Tal: Sinnar, Dist: Nashik.

Sub: Grant of "Final No Objection Certificate"

for your Plant Building on Plot NO: 971A-1A STICE,

Musalgaon, Sinnar Indl. Area.

Ref: i) This office Provisional No-Objection Certificate

No. MFS/160, Dated 26/05/2014.

ii)Application received from M/s. Nilkamal, Dt. 16/12/2014.

Dear Sir,

With reference to the above, a nominated officer of this office visited your plant on 23/01/2015 situated at above-mentioned address for inspection of fire fighting arrangements provided by you. Since the fire fighting arrangements provided by you were found in satisfactory working conditions this office is issuing a "Final"

No-Objection Certificate" for your following plant building:

Sr.	Building Name	Total Area
No.		In SQ. Mtrs
1 ,	Main Plant	7797.20
2	F.G.Storage	4007.72
3	Grinding Room	171.96
4	D.G. Room	62.27
5	Meter Room	10.43
6	Security Room	8.08
7	Change Room	53.76
8	Room	23.24
9	HT SW/ Yard	31.15
10	Room	20.12
11	HTOCB Room	28.40
12	Transformer	32.58
13	ACB Room	25.78
14	Transformer	35.20
15	Rest Room	94.88
16	Workers Rooms	208.19
13/	Workers Rooms	105.62
- 13	Total built up area in Sq. Mtrs	12716.66

..2/-

As per the provision of Section 3, Sub Section 3 of Maharashtra Fire Prevention and Life Safety Measures Act, 2006, it is the sole responsibility of Owner or Occupier as the case may be, that he/she shall furnish to Fire Advisor, MFS or local Fire Station Officer a Certificate in a 'Form B' issued by License Agency twice a year in the Month of January And July regarding maintenance of fire prevention and life safety measures and systems in good repair and efficient working condition.

Provisions of Maharashtra Fire Prevention and Life Safety

Measures Act, 2006

1. Under Section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.

Since the fire fighting arrangements provided by you under Section 3 of the said Act is found to be satisfactory and thus under <u>sub-section (3) of Section 3</u>, it is responsibility of the Owner or the Occupier as the case maybe, shall furnish to the Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of Jan & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in <u>sub-section (1)</u>.

3. <u>Under sub section (4) of Section 3</u>, no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other

person to do so.

As per the provisions of The Maharashtra Fire prevention & Life Safety Measures Act-06, M/s. Nilkamal Ltd. has also deposited an amount of Rs. 1,48,835/- (Rs. One Lac Forty Eight Thousand Eight Hundred Thirty Five Only) vide Receipt No. EBLVT14040375559,dated 03/04/2014.

The Fire Extinguishers & other safety system installed by you in the factory premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company.

Thanking you

Yours faithfully

(M.V. Deshmukh) Fire Advisor Govt. of Manarashtra.

