



FORM VI

DIRECTORATE OF FACTORIES & BOILERS, ODISHA

CERTIFICATE FOR USE OF A BOILER

(Renewal)

(Regulation 389)

Registry Number of Boiler : OD-08
Boiler Rating : 1747.0
Type of Boiler : Water Tube
Place and Year of manufacture : CHINCHWAD, PUNE, 2014

Maximum Continuous Evaporation : 65000.0 kg/hr
Name of Owner : M/s EMAMI PAPER MILL LTD
Situation of Boiler : BALGOPALPUR, RASALPUR, Dist- Balasore
Repairs : Repair order approved by Director of Factories and Boilers, Odisha.
Remarks : The Boiler is found in order.
Hydraulically tested on 25/09/2023 to 117.0 kg/cm²

I hereby certify that the above described Boiler is permitted by me under the provisions of Section 7/8 of the Boiler Act No. V of 1923 to be worked at a maximum pressure 78.0 kg/cm² for the period from 25/09/2023 to 24/09/2024

The loading of the Full lift spring loaded safety valve is not to exceed 78.0 kg/cm²

Fees Rs 18000.0

Paid on : 22/09/2023

Dated at Balasore

This 25th day of September 2023

Validity unknown

Digitally signed by KESAV NATH HANSOAH
Date: 2023.09.25 20:54:13 IST

Inspector of Boilers, Balasore

NOTE :

- This is a digitally signed electronically generated certificate and therefore needs no ink signed signature.
- This certificate is issued as per section 4, 5 & 6 of IT Act 2008 and its subsequent amendments in 2008.
- For verification, visit <https://portal.m-labour.odisha.gov.in>
- Tampering of this certificate will attract penal action.



FORM VI

DIRECTORATE OF FACTORIES & BOILERS, ODISHA

CERTIFICATE FOR USE OF A BOILER

(Renewal)

(Regulation 389)

Registry Number of Boiler : OD-48
Boiler Rating : 1747.0
Type of Boiler : Water Tube.
Place and Year of manufacture :
CHINCHWAD, PU
NE, 2014

Maximum Continuous Evaporation : 65000.0 kg/hr
Name of Owner : M/s EMAMI PAPER MILL LTD
Situation of Boiler : BALGOPALPUR, RASALPUR, Dist- Balasore
Repairs : Repair order approved by Director of Factories and Boilers, Odisha.
Remarks : The Boiler is found in order.
Hydraulically tested on 25/09/2023 to 117.0 kg/cm²

I hereby certify that the above described Boiler is permitted by me under the provisions of Section 7/8 of the Boiler Act No. V of 1923 to be worked at a maximum pressure 78.0 kg/cm² for the period from 25/09/2023 to 24/09/2024

The loading of the Full lift spring loaded safety valve is not to exceed 78.0 kg/cm²

Fees Rs. 18000.0

Paid on : 22/09/2023

Dated at Balasore

This 25th day of September 2023

Digitally signed by KODARNATH HANSDAH
Date: 2023.09.25 20:45:45 IST

Inspector of Boilers, Balasore

NOTE :

- This is a digitally signed electronically generated certificate and therefore needs no ink-signed signature.
- This certificate is issued as per section 4, 5 & 6 of TF Act 2000 and its subsequent amendments in 2008.
- For verification, visit <https://portal.dfo-labour.odisha.gov.in>
- Tampering of this certificate will attract penal action.



FORM VI
DIRECTORATE OF FACTORIES & BOILERS, ODISHA
CERTIFICATE FOR USE OF A BOILER
(Renewal)
(Regulation 389)

Registry Number of Boiler	: OR-670	Type of Boiler	: Water Tube
Boiler Rating	: 1526.0	Place and Year of manufacture	: TRICHY, 2000
Maximum Continuous Evaporation			: 35000.0 kg/hr
Name of Owner			: M/s EMAMI PAPER MILLS LTD.
Situation of Boiler			: BALGOPALPUR, BALASORE, Dist- Balasore
Repairs	: NA		
Remarks	: The Boiler is found in order.		
Hydraulically tested on	13/01/2023 to 90.0 kg/cm ²		

I hereby certify that the above described Boiler is permitted by me under the provisions of Section 7/8 of the Boiler Act No. V of 1923 to be worked at a maximum pressure 72.0 kg/cm² for the period from 13/01/2023 to 12/01/2024

The loading of the **FULL LIFT SPRING LOADED** safety valve is not to exceed 72.0 kg/cm²

Fees Rs. 11100.0

Paid on. : 22/12/2022

Dated at Balasore

This 16th day of January 2023

Digitally signed by K. S. ARNATH HANSDAH
Date: 2023.01.16 15:45:09 IST

Inspector of Boilers, Balasore

NOTE :

- This is a digitally signed electronically generated certificate and therefore needs no ink-signed signature.
- This certificate is issued as per section 4, 5 & 6 of IT Act 2000 and its subsequent amendments in 2008.
- For verification, visit <https://parashram-labour.odisha.gov.in>
- Tampering of this certificate will attract penal action.