



DAKSHIN HARYANA BILJI VITRAN NIGAM

(A Government of Haryana Undertaking)

Superintending Engineer 'OP' Circle-I

Mahendrapur, Gurugram

e-mail: scop1gurugram@dhbvn.org.in



To

✓ M/s Dishita Infra Pvt. Ltd.
P-8/17 DLF City Phase-II
Gurugram-122002 Haryana.
e-mail: infradishita@gmail.com

Memo No. Ch. 07 / Drg. -PLC


Dated: 18/04/2023

Sub: Power assurance for our proposed Affordable Group Housing Colony over an area measuring 4.25 acres in the revenue estate at village-Gopalpur Sector-99A, Gurugram. Declared load 3500 KW.

Ref: Your Firm Letter No. dated 05.04.2023.

It is conveyed that power requirement of your project bearing License No. 32 Of 2032 dated 14.02.2023 which is Valid upto 13.02.2028 shall be considered from the nearest 220/33 S/Stn. or any other source at the time of release of your load at 33 KV level or the level applied at the time of release of load. The load requirement of this project would be evaluated as per DHBVN norms. The assurance is subject the following conditions:-

1. Availability of power and infrastructure at the time of actual release of load.
2. Deposition of necessary charges by you as per instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary external & internal infrastructure as per approved Electrification Plan will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited applicant to get environment clearance from Pollution Control Board of Haryana.
5. The validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applying for revised assurance letter.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN, Gurugram for information.

