



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmol

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



0124-2322427

Fax
No.

0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s Kashish Developers Ltd.
Manor One, Sector-111, Dwarka Expressway
Gurugram (Haryana)
(E-mail: enfo.ncr@kashishgroup.com).

Memo No. Ch. 55 / Drg.-PLC

Dated: 16 / 11 / 2022

Sub:

Power Assurance for our Residential Group Housing colony on area measuring 14.843 acres (License No. 110 of 2011 dated 14.12.2011 valid upto 13.12.2024 falling in the revenue estate of Village- Chauma, Sector-111, Gurugram, Manesar Urban Complex. Declared load 1660KW with CD-1845KVA.

Ref:

Your firm letter No. Nil dated 28.10.2022 received in this office 31.10.2022 on the subject.

Reference your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing License No. 110 of 2011 dated 14.12.2011 which is valid upto 13.12.2024 shall be considered from the nearest 220/33KV S/Stn., Gurugram at the time of release of load. The voltage level of supply will be at 33KV level irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58-115 and Sec-37C and 37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per instructions of the Nigam and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulation.
3. The necessary 33/0.433 KV external & internal infrastructure will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN Gurugram w.r.t. his office Memo No.Ch-7/Drg.UL dated 15.11.2022.