



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

( A Government of Haryana Undertaking )  
Office of the gmol

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.



0124-2322427



Fax No. 0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

M/s Sadan Realtech Pvt. Ltd.  
M2K Corporate Park, 4th Floor, Block N,  
Mayfield Garden, Sec-51, Gurugram.  
Email:sadanreal@gmail.com

Memo No. Ch. 57/ Drg.-PLC

Dated: 17/11/2022

**Sub:** Request for power assurance/NOC for electrical load of 1860.06KVA connection from the DHBVN in respect of upcoming project namely M/s Sadan Realtech Pvt. Ltd. Affordable Residential Plotted Colony under DDJAY -2016 situated at Village-Dhanwapur, Sec-104, Gurugram, Haryana. Declared load 1860.06KVA.

**Ref:** Your firm letter No. Nil dated 07.11.2022 received in this office 14.11.2022.

Reference your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing License No. 174 of 2022 dated 21.10.2022 which is valid upto 20.10.2027 shall be considered from the nearest 220/33KV S/Stn., Gurugram at the time of release of load. The voltage level of supply will be at 33KV level irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58-115 and Sec-37C and 37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per instructions of the Nigam and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulation.
3. The necessary 33/0.433 KV external & internal infrastructure will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting approval of building plan from DGTCP Chandigarh.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.

  
Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN Gurugram w.r.t his office Memo No. Ch-5/Drg/UL dated 14.10.2022.