



भारत सरकार/Government of India
वाणिज्य और उद्योग मंत्रालय/Ministry of Commerce & Industry
पेट्रोलियम तथा विस्फोटक सुरक्षा संगठन (पेसो) /Petroleum & Explosives Safety Organisation (PESO)
डोर नं. ७-२०-१३, किरलामपुडी लेआउट
विशाखापट्टनम- 530017
Door No. 7-20-13, Kirlampudi Layout,
Visakhapatnam - 530017

ई-मेल:/E-mail : dyccevlzag@explosives.gov.in
फोन / फ़ैक्स नंबर:/Phone/Fax No : 0891-2722257
दिनांक/Dated : 08/09/2021

3 4 SEP 2021

अनुज्ञप्ति सं./No : S/HO/AP/03/772(S47418)

सेवा में/To,

M/S. MAITHAN ALLOYS LTD.,
C-17~ Panchavati Housing Colony~,
Akkilireddypalem,
Akkireddypalem,
Gajuwaka,
Taluka: Gajuwaka,
District: VISAKHAPATNAM,
State: Andhra Pradesh
PIN: 530012

विषय :/Sub : Plot No. 42 & 43,, APSEZ Atchuthapuram, Visakhapatnam, Gajuwaka, Taluka: Gajuwaka, District: VISAKHAPATNAM, State: Andhra Pradesh, PIN: 530012 स्थित LIQUID OXYGEN, गैस के संपीड़ित पात्र / पात्रों में भंडारण के लिए स्थिर एवं गतिशील दाब पात्र (अप्वलित) नियम, 2016 के अधीन स्वीकृत अनुज्ञप्ति संख्या S/HO/AP/03/772 के नवीनीकरण संबंध में /Storage of NLIQUID OXYGEN gas in pressure vessels at Plot No. 42 & 43,, APSEZ Atchuthapuram, Visakhapatnam, Gajuwaka, Taluka: Gajuwaka, District: VISAKHAPATNAM, State: Andhra Pradesh, PIN: 530012 - Licence No : S/HO/AP/03/772 grant in form LS-1A of SMPV(U) Rules, 2016-Renewal of Licence Regarding

महोदय/Sir
(s),

कृपया आपके दिनांक : 07/09/2021 के पत्र संख्या: OIN858352 का संदर्भ ग्रहण करें ।/Please refer to your application No.OIN858352 dated 07/09/2021 .

अनुज्ञप्ति संख्या : S/HO/AP/03/772 का नवीकरण दिनांक 30th सितंबर 2024 तक कर इसके साथ अग्रेषित की जा रही हैं ।

Licence Number: S/HO/AP/03/772 is renewed and is valid upto 30th September 2024 is forwarded herewith.

दिनांक 30/09/2024 से आगे अनुज्ञप्ति नवीनीकरण हेतु उपरोक्त नियम के नियम 55 के प्रावधानों का पालन किया जाए । विलंब शुल्क से बचने हेतु शुल्क के साथ मूल अनुज्ञप्ति तथा अन्य दस्तावेज अधिकतम दिनांक : 30 सितंबर, 2024 तक The Dy. Chief Controller of Explosives, Visakhapatnam में जरूर पहुंच जाने चाहिए ।
The provisions of the Rule 55 of the above said rules shall be followed for further renewal of the licence beyond 30/9/2024. The renewal application along with fees, Original licence and other documents shall reach in the Office of The Dy. Chief Controller of Explosives, Visakhapatnam, latest by 30th September, 2024 to avoid late fee.

कृपया अनुज्ञप्ति प्राप्ति की पावती दें ।/Please acknowledge the receipt of the licence.

भवदीय/Yours faithfully,

(J. Sarkar)

उप मुख्य विस्फोटक नियंत्रक
Dy. Chief Controller of Explosives
विशाखापट्टनम/Visakhapatnam

(For more information regarding status, fees and other details please visit our website <http://peso.gov.in>)

Note:-This is system generated document does not require physical signature.



FORM LS-1A/प्रारूप - एसएस-1क
(See Rules 50, 51, 54 and 55)/(नियम 50, 51, 54 और 55 देखें)
Licence to Store Compressed gas in pressure vessel or vessels
दाब पात्र या पात्रों में संपीड़ित गैस भण्डारण के लिए अनुज्ञप्ति



अनुज्ञप्ति सं/Licence No. : S/HO/AP/03/772(S47418)

फीस रुपए/Fee Rs. 27500/- per year/प्रति वर्ष

Licence is hereby granted to M/S. MAITHAN ALLOYS LTD., C-17~ Panchavati Housing Colony~, Akkireddypalem, Akkireddypalem, Gajuwaka, Taluka: Gajuwaka, District: VISAKHAPATNAM, State: Andhra Pradesh PIN: 530012 valid only for the storage of compressed gas in 1 Number(s) of pressure vessels as indicated below in the licensed premises described below and shown in the plan No.S/HO/AP/03/772(S47418) dated 16/08/2016 subject to the provisions of the Indian Explosives Act, 1884 (4 of 1884) and the rules made thereunder and to the further conditions of this licence.

श्री M/S. MAITHAN ALLOYS LTD., C-17~ Panchavati Housing Colony~, Akkireddypalem, Akkireddypalem, Gajuwaka, Taluka: Gajuwaka, District: VISAKHAPATNAM, State: Andhra Pradesh PIN: 530012 को नीचे वर्णित अनुज्ञप्त परिसरों में और रेखांकन संख्या S/HO/AP/03/772(S47418) dated 16/08/2016 में भारतीय विस्फोटक अधिनियम, 1884 (1884 का 4) और उसके अधीन बनाए गए नियमों तथा इस अनुज्ञप्ति की अन्य शर्तों पर 1 दाब पात्र / पात्रों में संपीड़ित गैस के भण्डारण के लिए अनुज्ञप्ति मंजूर की जाती है।

यह अनुज्ञप्ति 30 सितंबर 2024 तक प्रवृत्त रहेगी।

The Licence shall remain in force till the 30th September 2024.

Vessel No./वेसल नंबर	Name of Gas/गैस का नाम	State of Gas/गैस की स्थिति	Water Capacity in cubic meter/जल क्षमता (घ.मी.)	Max. working Pre. (kg/cm ²)/अधिकतम वर्किंग प्रेशर	Quantity Granted in kgs(Liquidified gas)/किलोग्राम में जारी मात्रा (लिक्विफाईड गैसेस)
10T0080	LIQUID OXYGEN	Liquidified	13.52	18.54	13885
Total Water capacity			13.52		

April 12, 2012

sd -
For Chief Controller of Explosives
HQ, Nagpur
कृते मुख्य विस्फोटक नियंत्रक
नागपुर

1). Amendment dated - 16/08/2016

DESCRIPTION AND LOCATION OF THE LICENSED PREMISES/अनुज्ञप्त परिसर का विवरण और अवस्थिति

The licensed premises, the layout boundaries and other particulars of which are shown in the attached approved plan No. S/HO/AP/03/772 dated 16/08/2016 are situated at Gajuwaka/Visakhapatnam and consists of 1 Number(s) vessel(s) for storage of :अनुज्ञप्त परिसर, प्रदर्शित सीमा और अन्य विवरण जो संलग्न अनुमोदित रेखाचित्र क्र.S/HO/AP/03/772 दिनांक 16/08/2016 में दर्शाए गए हैं Gajuwaka/Visakhapatnam पर स्थित हैं और इसमें 1 वेसल सम्मिलित है।

a) Flammable/Corrosive/Toxic Gases :ज्वलनशील / संक्षारक / विषैली गैसों:

b) Non-Toxic Gases :अविषैली गैसों : LIQUID OXYGEN

and is situated at PlotNo : 42 & 43, Village/Town :Gajuwaka/Visakhapatnam Police Station : Atchutapuram District : VISAKHAPATNAM, State: Andhra Pradesh , Pin : 53. /प्लॉट संख्या PlotNo : 42 & 43, गांव या नगर :Gajuwaka/Visakhapatnam पुलिस थाना Atchutapuram जिला VISAKHAPATNAM राज्य Andhra Pradesh , Pin : 53 में स्थित है।

SPACE FOR ENDORSEMENT OF RENEWALS/नवीकरण के पृष्ठानक के लिए स्थान

	Date of Renewal/नवीकरण की तारीख	Date of Expiry/अनुज्ञप्ति की समाप्ति की तारीख	Signature and stamp of the licensing authority/अनुज्ञापन प्राधिकारी के हस्ताक्षर और कार्यालय की मुद्रा
This licence shall be renewable without any concession in fee for three years in the absence of contravention of the provision of the Indian Explosives Act, 1884, or the Static and Mobile Pressure Vessels (Unfired) Rules, 2016, framed thereunder or of the conditions of the licence./अनुज्ञप्ति, भारतीय विस्फोटक अधिनियम, 1884 या उसके अधीन अथवा बनाए गए स्थिर एवं गतिशील दाब पात्र (अज्वलित) नियम, 2016 या इस अनुज्ञप्ति की शर्तों का उल्लंघन न होने की दशा में, फीस में बिना किसी छूट के तीन वर्ष तक नवीकृत की जाएगी।	08/09/2021	30/09/2024	 J. Sarkar DCCE For Dy. Chief Controller of Explosives, Visakhapatnam Dy. Chief Controller of Explosives, Visakhapatnam

This licence is liable to be cancelled if the licenced premises are not found conforming to the description and conditions attached hereto and contravention of any of the rules and conditions under which this licence is granted and the holder of this licence is also punishable with imprisonment for the term which may extend to two years or with fine which may extend to three thousand rupees or with both./यदि निरीक्षण के समय अनुज्ञप्त परिसर इससे उपाबद्ध विवरण और शर्तों के अनुरूप नहीं पाया जाता है और जिन नियमों और शर्तों के अधीन यह अनुज्ञप्ति मंजूर की गई है, उनमें से किसी का उल्लंघन होता है तो उस दशा में यह अनुज्ञप्ति रद्द की जा सकती है और अनुज्ञप्ति का धारक कारावास से, जिसकी अवधि दो वर्ष तक की हो सकेगी, या जुर्माने से, जो तीन हजार रुपये तक का हो सकेगा, या दोनों से दण्डनीय भी होगा।

Note:-This is system generated document does not require physical signature.

Conditions of FORM LS-1A

License No. :S/HO/AP/03/772(S47418)

1. The licensed premises shall conform to the description of location and facilities and to the approved plan, as mentioned on the body of the licence.
2. The licensed premises shall have prominently marked thereon the number of the licence held for it.
3. The emergency telephone numbers of local fire service, police and the principal marketing company or supplier of the compressed gas, and emergency instructions shall be conspicuously displayed in the licensed premises.
4. The licensed premises shall not be used for any purpose other than the purpose for which the licence is granted.
5. The compressed gas shall be stored only in the vessels specified in the licence and shown in the approved plan attached hereto.
6. The storage vessel shall at all times maintain requisite safety distance from any other facility, building, boundary, fencing or protected works as specified in appropriate Table specified in rule 22.
7. A suitable hard stand for parking of the vehicle during loading or unloading of any compressed gas shall be provided. The following minimum safety distances shall be provided between the centre of the hard stand and the storage vessel or boundary line of installation; as well as between the loading or unloading points and storage vessel or boundary line of installation as specified under item (ii) of sub-rule 5 of Rule 27.
8. All fittings of the vessel shall be maintained in good operating condition.
9. No alteration of the position of the vessel and no replacement of the vessel shall be effected except with the previous sanction, in writing, of the licensing authority as provided in the rules.
10. Every vessel before being repaired or exhumed shall be made free of compressed gas and thoroughly cleaned in a safe manner. When a vessel is opened for cleaning or repairs, no lamp of any description either ordinary or electric, electric cables or fans and no articles, appliances or equipment capable of igniting flammable vapours shall be brought near the vessel.
11. No person shall cause to repair or repair either by the use of fire, welding, hot riveting or brazing any vessel used for the storage of flammable gas unless it has been thoroughly cleaned and gas-free or otherwise prepared for safely carrying out such hot work and certified in writing, by a competent person, to have been so prepared. Where the vessel has been certified as gas-free, the certificate shall be preserved by the licensee for a period of not less than three months and produced to the licensing authority on demand.
12. No person shall enter any vessel used for the storage of a toxic or corrosive gas unless he is adequately protected by means of protective clothing, gas masks and such other equipments as may be required in the specific case.
13. Compressed gas shall be filled into or removed from the vessel through designated pipes of required specification and through transfer facilities shown in the approved plan.
14. The vessel shall not be filled between the hours of sunset and sunrise, unless adequate lighting of approved type is provided and except in such manner and such other condition or conditions as are specifically endorsed on the licence by the licensing authority.
15. All operations in the licensed premises shall be carried out by persons competent in such operation. Every person managing or employed on or in connection with the licensed premises shall abstain from any act whatsoever which tends to cause fire or explosion and which is not reasonably necessary and to the best of his ability, shall prevent any other person from doing such act.
16. The licensee shall provide for each licensed premises a minimum of two portable foam type or dry chemical type fire extinguishers of 9 kg. capacity each, which shall be kept ready at convenient location for immediate use in the event of any fire in addition to other fire fighting or other mitigating facilities required for flammable or toxic gases.
17. All valves in the premises must be permanently marked in a manner clearly indicating the direction of opening and shutting the valve.
18. Free access to the licensed premises shall be given at all reasonable times to any of the officers specified in rule 70 and every facility shall be afforded to such officer for ascertaining that the rules and the conditions of this licence are duly observed.
19. If the licensing authority calls upon the holder of a licence by a notice in writing to execute any repairs in the licensed premises which are, in the opinion of such authority, necessary for the safety of the premises, the holder of the licence shall execute the repairs within such period as may be specified in the notice.
20. Every vessel shall be outside any building and shall be supported on well designed calculations.
21. No artificial light capable of igniting flammable vapour shall at any time be present within nine meters of the vehicle and the loading or unloading points during the transfer of the compressed gas and no person engaged in such transfer shall smoke.
22. All electrically equipment such as motors switches, starters used for transfer of liquefied petroleum gas shall be of flameproof construction conforming to IS/IEC 60079-1 to 11 or of a type approved by the Chief Controller.
23. Smoking, naked lights, lamps, source of fire or any other stimulant capable of igniting flammable vapours shall not be allowed inside the premises. Every person managing or employed on or in connection with licensed premises shall abstain from any act whatsoever which tends to cause fire or explosion and which is not reasonably necessary and to the best of his ability, shall prevent any other person from doing such act.
24. Any accident, fire, explosion or untoward incident occurred within the licensed premises shall be immediately reported to the Chief Controller of Explosives, Controller, nearest police station and District Magistrate by quickest mode of communication.

For The Dy. Chief Controller of Explosives, Visakhapatnam