

**(THIS CERTIFICATE MUST BE HUNG UP IN THE BOILER HOUSE)**  
**(FORM VI)**  
**CHHATTISGARH BOILER INSPECTION DEPARTMENT**  
**CERTIFICATE FOR THE USE OF A BOILER**  
**(REGULATION 389)**

Certificate No : 224131729732

Reference No : 2940476050

Udyam Aakanksha No. - 11503474848142

Registry No Of Boiler -CG/1056

Type Of Boiler - **cbc**

Place & Year Of Manufacture -China2012

Boiler Rating - **4051**

Maximum Continuous Evaporation(TPH) - **135**

Name Of Owner - **Shri Ganesan Kumar**

Situation Of Boiler - **Chakabura**

Enterprise Name - **ACB India ltd**

Repairs - **2023- nil**

Remark - **1. To steam under direct charge of certified BOEs and 1st class BA only. 2. To offer for steam test.**

Hydraulically Tested On - **27/10/2023**

to **130 Kg/cm<sup>2</sup>**

I hereby certify that the above described boiler is permitted by Me / The Chief Inspector under the provisions of Section 7 or 8 of the Boilers Act, No. V of 1923, to be worked at a maximum pressure of **102.9 Kg/cm<sup>2</sup>** for the period from **27/10/2023 To 26/10/2024**

The Loading of the **DSL** safety valve is not to exceed **102.9 Kg/cm<sup>2</sup>**

Fee Rs. **22000** paid on **18/10/2023**

Dated at: **30/10/2023**

Countersigned

Generated On- 30/10/2023 11:26:14



**Dwarika Verma**

OPEN UP BOILER FOR CLEANING  
AFTER EVERY 26 WEEK(S) AND KEEP RECORD

*Inspector Of Boilers*

This is computer generated certificate and does not require seal and signature. This certificate can be verified online at <http://cg.nic.in/boiler> through Ref No. and Certificate No.