

(THIS CERTIFICATE MUST BE HUNG UP IN THE BOILER HOUSE)

(FORM VI)

**CHHATTISGARH BOILER INSPECTION DEPARTMENT
CERTIFICATE FOR THE USE OF A BOILER
(REGULATION 389)**

Certificate No : 224131729659

Reference No : 2390102655

Udyam Aakanksha No. - 11501326898045

Registry No Of Boiler - **CG/735**

Type Of Boiler - **cbc**

Place & Year Of Manufacture - **Yamunanagar 2015**

Boiler Rating - **12484**

Maximum Continuous Evaporation(TPH) - **215**

Name Of Owner - **Shri Sanjay Kumar Azad**

Situation Of Boiler - **RATIJA**

Enterprise Name - **A.C.B.(India) Limited**

Repairs - **2023- nil**

Remark - **1. To steam under direct charge of certified BOEs and 1st class BA only. 2. To offer for steam test.**

Hydraulically Tested On - **09/11/2023**

to **169 Kg/cm²**

I hereby certify that the above described boiler is permitted by Me / The Chief Inspector under the provisions of Section 7 or 8 of the Boilers Act, No. V of 1923, to be worked at a maximum pressure of **135 Kg/cm²** for the period from **09/11/2023** To **08/11/2024**

The Loading of the **DSL** safety valve is not to exceed **135 Kg/cm²**

Fee Rs. **10** paid on **20/10/2023**

Dated at: **10/11/2023**

Countersigned

Generated On- 10/11/2023 10:45:39



Dwarika Verma

Inspector Of Boilers

OPEN UP BOILER FOR CLEANING
AFTER EVERY 26 WEEK(S) AND KEEP RECORD

This is computer generated certificate and does not require seal and signature. This certificate can be verified online at <http://cg.nic.in/boiler> through Ref No. and Certificate No.