

(THIS CERTIFICATE MUST BE HUNG UP IN THE BOILER HOUSE)
(FORM VI)
CHHATTISGARH BOILER INSPECTION DEPARTMENT
CERTIFICATE FOR THE USE OF A BOILER
(REGULATION 389)

Certificate No : 224131728732

Reference No : 3768197866

Udyam Aakanksha No. - 11500842896672

Registry No Of Boiler -CG/570

Type Of Boiler - cbc

Place & Year Of Manufacture -Jianghu2009

Boiler Rating - 9774

Maximum Continuous Evaporation(TPH) - 250

Name Of Owner - Shri Ashish Kumar Jain

Situation Of Boiler - Renki Chainpur Korba

Enterprise Name - A.C.B.(India) Limited

Repairs - 2023- nil

Remark - 1. To steam under direct charge of certified BOEs and 1st class BA only. 2. To offer for steam test. 3. To keep close watch over screen superheater coils.

Hydraulically Tested On - 03/04/2023

to 164 Kg/cm²

I hereby certify that the above described boiler is permitted by Me / The Chief Inspector under the provisions of Section 7 or 8 of the Boilers Act, No. V of 1923, to be worked at a maximum pressure of 131.03 Kg/cm² for the period from 03/04/2023 To 02/04/2024

The Loading of the DSL safety valve is not to exceed 131 Kg/cm²

Fee Rs. 36000 paid on 22/03/2023

Dated at: 01/05/2023

Countersigned

Generated On- 01/05/2023 12:57:32



Dwarika Verma

OPEN UP BOILER FOR CLEANING
AFTER EVERY 26 WEEK(S) AND KEEP RECORD

Inspector Of Boilers

This is computer generated certificate and does not require seal and signature. This certificate can be verified online at <http://cg.nic.in/boiler> through Ref No. and Certificate No.