

FORM VI

(Regulation 389)

CERTIFICATE FOR USE OF A BOILER

NO: DDB-01/BLR/CFN-208/2023-24

Dated : 26/02/2024

GSC.NO : IS0FB0000093225

Dated : 26/02/2024

Reg. No. of Boiler : KTK-5921

Type of Boiler : H M T Package Boiler

Boiler Rating : 90.0 sq_Mts

Place and year: Chichwad-2021
of manufacture

Maximum Continuous Evaporation :

4.0 TPH

Name of the Owner :

APL Apollo Tubes Ltd

Situation of Boiler :

Plot no 53, Part 1, 4th Phase, Sy
no-28-33, Kurandanahalli Village, Kasaba Hobli,
563130
NIL

Repairs :

Remarks :

OI AND HT FOUND SATISFACTORY

Hydraulically Tested on 26/02/2024 to 15.0 Kg/Sq.cm(g)

I hereby certify that the above described boiler is permitted by me under the provisions of Section 7/8 of the Indian Boiler Act, (No. V of 1923), to be worked at a maximum pressure of 10.54 Kg/Sq.Cm(g) for the period from 26/02/2024 to 25/02/2025.

The loading of the 40X80 MM SLSV (2) safety valve is not to exceed 10.54 Kg/Sq. Cm(g).

Fee Rs.3400 (Boiler)+0 (SteamLine) Paid on 26/02/2024 at

Dated at This 26th day of February ,2024

Deputy Director of Boilers, Division-1, Bengaluru

Competent Person
Deputy Director of Boilers
Division-1, Bangalore

Open up for cleaning after every 08 Weeks. See on the reverse for the conditions and keep record.

CONDITIONS
(Reverse of Form VI)

- (1) No structural alteration, addition or renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act.
- (2) Under the provisions of Section 8 of the Act this certificate shall cease to be in force:
- (a) on the expiry of the period for which it was granted; or
 - (b) when any accident occurs to the boiler; or
 - (c) when the boiler is moved the boiler not being vertical boiler the heating surface of which is less than eighteen point fifty eight square meters (18.58 Sq. Mts) , or a portable or vehicular boiler; or
 - (d) when any structural alteration, addition or renewal is made in or to the boiler; or
 - (e) if the Chief Inspector in any particular case so directs when any structural alteration, addition or renewal is made in or to any steam-pipe attached to the boiler; or
 - (f) on the communication to the owner of the boiler of an order of the Chief Inspector or Inspector prohibiting its use on the ground that it or any steam-pipe attached thereto is in a dangerous condition.

Under Section 10 of the Act, when the period of a certificate relating to a boiler has expired, the owner shall, provided that he has applied before the expiry of that period for a renewal of the Certificate, be entitled to use the boiler at the maximum pressure entered in the former certificate, pending the issue of orders on the application but this shall not be deemed to authorise the use of a boiler in any of the cases referred to in clause (b), (c), (d), (e) and (f) of sub-section (1) of section 8 occurring after the expiry of the period of the certificate.

- (3) The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the safety valve set to a pressure exceeding such maximum pressure.
- (4) The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working.

NOTE.- The particulars and dimensions regarding this boiler may be obtained by the owner on payment in the prescribed manner on application to the Chief Inspector.

Signature Not Verified



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಕಾರ್ಖಾನೆಗಳು, ಬಾಯ್ಲರುಗಳು, ಕೈಗಾರಿಕಾ ಸುರಕ್ಷತೆ ಮತ್ತು ಸ್ವಾಸ್ಥ್ಯ ಇಲಾಖೆ

☎ 080 -29753051

✉ ddbbmttc@gmail.com

🌐 www.esuraksha.karnataka.gov.in

ಬಾಯ್ಲರುಗಳ ಉಪ ನಿರ್ದೇಶಕರ ಕಛೇರಿ,

ವಿಭಾಗ-1, ಬೆಂಗಳೂರು, ಕಲ್ಯಾಣ ಸುರಕ್ಷಾ ಭವನ,

ನೆಲ ಮಹಡಿ, ಬನ್ನೇರುಘಟ್ಟ ರಸ್ತೆ, ಬೆಂಗಳೂರು-560029.

ಸಂ:ಬಾಲುನಿ/ವಿ-1ಬೆಂ/ಬಿಎಲ್‌ಆರ್/ಐಎನ್‌ಎಸ್/2023-24

ದಿನಾಂಕ: 26.02.2024

ರವರಿಗೆ,

M/s, Apollo tubes ltd.,
Plot No-53, part -01, 4th phase, Indl.area,
sy no-28-33, kurandahalli village,
Malur kolar-563101
ಮಾನ್ಯರೇ,

ವಿಷಯ: ತಮ್ಮಲ್ಲಿರುವ ಬಾಯ್ಲರ್ ನಂಬರ್ **KTk-5921** ರ ಪ್ರಮಾಣಪತ್ರದ ಬಗ್ಗೆ ಕುರಿತು.

====***=====

ದಿನಾಂಕ: **26-02-2024** ರಂದು ತಮ್ಮ ಬಾಯ್ಲರನ್ನು ನಾನು ಪರಿವೀಕ್ಷಿಸಿರುವುದು ಸರಿಯಷ್ಟೇ, ಸದರಿ ಬಾಯ್ಲರ್‌ಗೆ ದಿನಾಂಕ: **25-02-2025** ರವರೆಗೆ ನವೀಕರಿಸಿದ ಪ್ರಮಾಣಪತ್ರವನ್ನು ತಮ್ಮ ಅವಗಾಹನೆಗೆ ಹಾಗೂ ಬಾಯ್ಲರ್‌ನ ಮನೆಯಲ್ಲಿ ಪ್ರದರ್ಶಿಸಲು ಇದರ ಜೊತೆ ಲಗತ್ತಿಸಲಾಗಿದೆ. ತಮ್ಮ ಬಾಯ್ಲರ್‌ನ ಪ್ರಮಾಣಪತ್ರದ ಗಡುವು ಮುಗಿಯಲು ಇನ್ನೂ ಒಂದು ತಿಂಗಳು ಇದೇ ಎನ್ನುವಾಗಲೇ ನವೀಕರಿಸಲು ಬಯಸಿದ್ದಲ್ಲಿ ಬಾಯ್ಲರ್ ಪರಿವೀಕ್ಷಣೆಗೆ ನಿಗದಿತ ಶುಲ್ಕದೊಂದಿಗೆ ಈ ಕಛೇರಿಗೆ ಅರ್ಜಿಯನ್ನು ನಮೂನೆ-ಜೆ ಅನ್ನು ಸಲ್ಲಿಸಲು ತಮಗೆ ಈ ಮೂಲಕ ತಿಳಿಸಿದೆ.

ಬಾಯ್ಲರ್ ಚಾಲ್ತಿಯಲ್ಲಿರುವಾಗ ಪ್ರತಿ ಪಾಳಿಗೆ ಒಬ್ಬರಂತೆ ಕಾನೂನು ರೀತ್ಯಾ ಬೇಕಾದ ಆಧಿಕೃತ ಪ್ರಮಾಣಪತ್ರ ಹೊಂದಿದ ಬಾಯ್ಲರ್ ಆಪರೇಷನ್ ಇಂಜಿನಿಯರ್ಸ್ ಅಥವಾ ಬಾಯ್ಲರ್ ಅಟೆಂಡೆಂಟ್‌ಗಳ ಉಸ್ತುವಾರಿಯಲ್ಲೇ ನಡೆಸಲು ಸಹ ತಮಗೆ ಈ ಮೂಲಕ ಸೂಚಿಸಿದೆ.

ಅಡಕ: ನಮೂನೆ-VI

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

(ಎಂ ಎಚ್ ಚಿಕ್ಕಮುನಿಯಪ್ಪ)

ಬಾಯ್ಲರುಗಳ ಉಪ ನಿರ್ದೇಶಕರು

ವಿಭಾಗ-1, ಬೆಂಗಳೂರು.

