

FORM VI

(Regulation 389)

CERTIFICATE FOR USE OF A BOILER

NO: ADB-03/BLR/CFN-190/2023-24

Dated : 30/01/2024

GSC.NO : IS0FB0000092365

Dated : 30/01/2024

Reg. No. of Boiler : KTK-5591

Type of Boiler : HMT Package

Boiler Rating : 64.0 sq_Mts

Place and year: Vadodara-2018

of manufacture

Maximum Continuous Evaporation :

3.0 TPH

Name of the Owner :

APL Apollo Tubes Ltd

Situation of Boiler :

Plot no 53, Part 1, 4th Phase, Sy
no-28-33, Kurandanahalli Village, Kasaba Hobli,
563130

Repairs :

NIL

Remarks :

OI AND HT FOUND SATISFACTORY

Hydraulically Tested on 30/01/2024 to 15.0 Kg/Sq.cm(g)

I hereby certify that the above described boiler is permitted by me under the provisions of Section 7/8 of the Indian Boiler Act, (No. V of 1923), to be worked at a maximum pressure of 10.54 Kg/Sq.Cm(g) for the period from 30/01/2024 to 29/01/2025.

The loading of the 25*50 MM SLSV-2 safety valve is not to exceed 10.54 Kg/Sq. Cm(g).

Fee Rs.2700 (Boiler)+7800 (SteamLine) Paid on 31/01/2024 at

Dated at This 31th day of January ,2024

Deputy Director of Boilers, Division-1, Bengaluru

Competent Person
Deputy Director of Boilers
Division-1, Bangalore

Open up for cleaning after every 08 Weeks. See on the reverse for the conditions and keep record.