

376 88

Y. P. P. 316 Bks. (50 Lvs.)-8-2017-AZ12"x12"-S (Y) 414
C. M. P. & S. D., No. 5710/34/E, dated 23-2-42.]

Counterfoil

[THIS CERTIFICATE MUST BE HUNG UP IN THE BOILER HOUSE]

FORM VI

No :

Date :

24 JUL 2023

19

Registry No. of Boiler : ...MR/15763..... Type of ~~WATER~~ TUBE.....

34167 Sq. M SHANGHAI, CHAINA 2011
Boiler Rating : Place and Year of Manufacture :

Maximum continuous evaporation :

Name of Owner GMR WARORA ENERGY LIMITED,
B-1, MOHABALA MIDC, GROWTH CENTRE, POST & Tah. WARORA
DIST: CHANDRAPUR PIN: 442907

Situation of Boiler :

Repairs : 2016 - Few water wall tubes partially renewed

Remarks :

2023 - Certificate issued U/R 376 (If) of IBR-1950 & Boiler tube entirely bared of Reg. 391
tube complied with.

Hydraulically teste ort : 25/08/2022 to 252.25 Kg./Cm.²

Maximum pressure permitted 201.80 Kg./Cm.² for

the period from 25/08/2023 to 24/08/2024

The loading of the boiler on S.D. not to exceed 201.8 kg/cm² safety valves not
not to exceed 183.56 kg/cm² CWS SDL= --- mm SDR= --- mm SH= --- mm
to exceed

The main steam pipe tested hydraulically to a pressure of Kg./Cm.²
last on

Fee Rs. 97000 /- paid on 14/07/2023

Dated at NAGPUR

This 20 July 2023 day of

Jt./ Dy. Director of Steam Boilers,
Maharashtra State, Nagpur.

OPEN UP BOILER FOR CLEANING
AFTER EVERY WEEK
AND KEEP RECORD

Director.

