



ENVIROCHECK

Recognised by MoEF&CC, WBPCB & JSPCB
Certified by ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018



TEST REPORT

FORMAT NO: ENV/FM/38

Name of the Project	: Shiga Energy Pvt. Ltd. (2 x 48.5 MW)	Type of Project	: Hydro Electric Project
Address	: Power House Tashiding, Hydro Electric Project, Kagaythang, P.O. - Yangtay, Geyzing, West Sikkim - 737111	Sampling Date	: 06.06.2023
		Period of Analysis	: 10.06.2023 - 13.06.2023
		Date of Issue	: 12.06.2023
Sampling Plan & Procedure	: ENV/SOP/01	Deviation from the Sampling Method and Plan	: No
		Type of Sample	: Stack Emission
Sample Condition	: Sealed	Sample ID No.	: ENV/71/M/A/I
		Report No.	: ENV/71/M/TR(A)/1/23-24

A. GENERAL INFORMATION ABOUT STACK PROVIDED BY THE INDUSTRY

Stack Attached to	: D. G. - 500 KVA (Acoustic Enclosure attached)	Height of Stack (mtr.) (from G. L.)	: 6.7056
Shape of Stack	: Circular	Stack I.D. at sampling point (mtr.)	: 0.3048
Materials of Construction	: M.S.	Height of sampling port (mtr.) (from G.L.)	: Final Exhaust
Capacity	: 500 KVA		
Emission Due to	: Combustion of H.S.D	Permanent Platform & Ladder	: No
Fuel Used	: H.S.D		
Working Fuel Consumption	: 36 liter./hr.		
Pollution Control Device	: Nil		

B. RESULTS

SL. NO.	PARAMETERS	UNIT	METHOD NO.	RESULTS	LIMIT
1.	Flue Gas Temperature	°C	IS : 11255 (Part 1)	245.0	N.A.
2.	Barometric Pressure	mm of Hg.	--	744.0	N.A.
3.	Velocity of Gas flow	m/s	IS : 11255 (Part 3)	16.53	N.A.
4.	Quantity of Gas flow	Nm ³ /hr.	IS : 11255 (Part III)	2440.94	N.A.
5.	Concentration of SO ₂	mg/Nm ³	IS 11255 (Part 2) : 2019	39.17	N.A.
6.	Concentration of NO _x	mg/Nm ³	IS 11255 (Part 7) : 2017 / ASTM D 1608-98, Sec. 11 (Vol. 11.07) : 2017	46.50	N.A.
7.	Concentration of CO ₂	% (v/v)	IS 13270 : 2019	7.8	N.A.
8.	Concentration of CO	% (v/v)	IS 13270 : 2019	<1.0	10
9.	Concentration of Particulate Matter	mg/Nm ³	IS 11255 (Part -1) : 2019 & ASTM D 3685/D 3685M-98 (reapproved 2005) : Sec. 11 (Vol. 11.07) : 2017	41.55	150.0

Remarks : Limit as per CPCB [Emission Regulation Part IV : COINDS/26/1986-87].
: N.A. means Not Available.
: During monitoring temporary ladder and platform were provided.

Reviewed By:
DURBADAL CHAKRABORTY

Dy. Quality Manager

Authorised Signatory:

INDRANI BHATTACHARYA
Dy. Technical Manager, Chemical



ENVIROCHECK

Recognised by MoEF&CC, WBPCB & JSPCB
Certified by ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018



TEST REPORT

FORMAT NO : ENV-FM/38

Name of the Project	: Shiga Energy Pvt. Ltd. (2 x 48.5 MW)	Type of Project	: Hydro Electric Project
Address	: Sakyong, Geyzing, West Sikkim, Sikkim - 737111	Sampling Date	: 06.06.2023
		Period of Analysis	: 10.06.2023 - 11.06.2023
		Date of Issue	: 12.06.2023
Sampling Plan & Procedure	: ENV/SOP/01	Deviation from the Sampling Method and Plan	: No
		Type of Sample	: Stack Emission
Sample Condition	: Sealed	Sample ID No.	: ENV/71/M/A/II
		Report No.	: ENV/71/M/TR(A)/II/23-24

A. GENERAL INFORMATION ABOUT STACK PROVIDED BY THE INDUSTRY

Stack Attached to	: D. G. - 30 KVA (Acoustic Enclosure attached)	Height of Stack (mtr.) (from G. L.)	: 2.95
Shape of Stack	: Circular	Stack I.D. at sampling point (mtr.)	: 0.0507
Materials of Construction	: M.S.	Height of sampling port (mtr.) (from G.L.)	: Final Exhaust
Capacity	: 30 KVA		
Emission Due to	: Combustion of H.S.D	Permanent Platform & Ladder	: No
Fuel Used	: H.S.D		
Working Fuel Consumption	: 03 liter./hr.		
Pollution Control Device	: Nil		

B. RESULTS

SL. NO.	PARAMETERS	UNIT	METHOD NO.	RESULTS	LIMIT
1.	Flue Gas Temperature	°C	IS : 11255 (Part 1)	85.0	N.A.
2.	Barometric Pressure	mm of Hg.	--	744.0	N.A.
3.	Velocity of Gas flow	m/s	IS : 11255 (Part 3)	11.49	N.A.
4.	Quantity of Gas flow	Nm ³ /hr.	IS : 11255 (Part III)	67.37	N.A.
5.	Concentration of SO ₂	mg/Nm ³	IS 11255 (Part 2) : 2019	17.69	N.A.
6.	Concentration of NO _x	mg/Nm ³	IS 11255 (Part 7) : 2017 / ASTM D 1608-98, Sec. 11 (Vol. 11.07) : 2017	21.52	N.A.
7.	Concentration of CO ₂	% (v/v)	IS 13270 : 2019	7.0	N.A.
8.	Concentration of CO	% (v/v)	IS 13270 : 2019	<1.0	1.0
9.	Concentration of Particulate Matter	mg/Nm ³	IS 11255 (Part - 1) : 2019 & ASTM D 3685 / D 3685M-98 (reapproved 2005) : Sec. 11 (Vol.11.07) : 2017	16.52	150.0

Remarks : Limit as per CPCB [Emission Regulation Part IV : COINDS/26/1986-87].
: N.A. means Not Available.
: During monitoring temporary ladder and platform were provided.

Reviewed By :

DURBADAL CHAKRABORTY

Dy. Quality Manager

Authorised Signatory :

INDRANI BHATTACHARYA
Dy. Technical Manager, Chemical



ENVIROCHECK

Recognised by MoEF&CC, WBPCB & JSPCB
Certified by ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018



TEST REPORT

FORMAT NO.: EN/FM/38

Name of the Project	: Shiga Energy Pvt. Ltd. (2 x 48.5 MW)	Type of Project	: Hydro Electric Project
Address	: Kabirthing, Geyzing, Saktong, West Sikkim, Pin - 737111	Sampling Date	: 06.06.2023
		Period of Analysis	: 10.06.2023 - 10.06.2023
		Date of Issue	: 12.06.2023
Sampling Plan & Procedure	: ENV/SOP/01	Deviation from the Sampling Method and Plan	: No
		Type of Sample	: Stack Emission
Sample Condition	: Sealed	Sample ID No.	: ENV/71/M/A/III
		Report No.	: ENV/71/M/TR(A)/II/23-24

A. GENERAL INFORMATION ABOUT STACK PROVIDED BY THE INDUSTRY

Stack Attached to	:	D. G. – 30 KVA (Acoustic Enclosure attached)			
Shape of Stack	:	Circular	Height of Stack (mtr.) (from G. L.)	:	2.95
Materials of Construction	:	M.S.	Stack I.D. at sampling point (mtr.)	:	0.0507
Capacity	:	30 KVA	Height of sampling port (mtr.) (from G.L.)	:	Final Exhaust
Emission Due to	:	Combustion of H.S.D			
Fuel Used	:	H.S.D	Permanent Platform & Ladder	:	No
Working Fuel Consumption	:	03 liter./hr.			
Pollution Control Device	:	Nil			

B. RESULTS

SL. NO.	PARAMETERS	UNIT	METHOD NO.	RESULTS	LIMIT
1.	Flue Gas Temperature	°C	IS : 11255 (Part 1)	: 83.0	N.A.
2.	Barometric Pressure	mm of Hg.	--	: 744.0	N.A.
3.	Velocity of Gas flow	m/s	IS : 11255 (Part 3)	: 10.07	N.A.
4.	Quantity of Gas flow	Nm ³ /hr.	IS : 11255 (Part III)	: 59.38	N.A.
5.	Concentration of SO ₂	mg/Nm ³	IS 11255 (Part 2) : 2019	: 12.70	N.A.
6.	Concentration of NO _x	mg/Nm ³	IS 11255 (Part 7) : 2017 / ASTM D 1608-93, Sec. 11 (Vol. 11.07) : 2017	: 16.22	N.A.
7.	Concentration of CO ₂	% (v/v)	IS 13270 : 2019	: 6.8	N.A.
8.	Concentration of CO	% (v/v)	IS 13270 : 2019	: <1.0	1.0
9.	Concentration of Particulate Matter	mg/Nm ³	IS 11255 (Part - 1) : 2019 & ASTM D 3685, D 3685M-98 (reapproved 2005) : Sec. 11 (Vol. 11.07) : 2017	: 14.12	150.0

Remarks : Limit as per CPCB [Emission Regulation Part IV : COINDS/26/1986-87].
: N.A. means Not Available.
: During monitoring temporary ladder and platform were provided.

Reviewed By:

DURBADAN CHAKRABORTY

Dy. Quality Manager

Authorised Signatory:

INDRANI BHATTACHARYA
Dy. Technical Manager, Chemical



ENVIROCHECK

Recognised by MoEF&CC, WBPCB & JSPCB
Certified by ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018



TEST REPORT

FORMAT NO : ENV/FM/38

Name of the Project	: Shiga Energy Pvt. Ltd. (2 x 48.5 MW)	Type of Project	: Hydro Electric Project
Address	: Barrage Sedang, West Sikkim, Sikkim - 737111	Sampling Date	: 06.06.2023
		Period of Analysis	: 10.06.2023 - 10.06.2023
		Date of Issue	: 12.06.2023
Sampling Plan & Procedure	: ENV/SOP/01	Deviation from the Sampling Method and Plan	: No
		Type of Sample	: Stack Emission
Sample Condition	: Sealed	Sample ID No.	: ENV/71/M/A/IV
		Report No.	: ENV/71/M/TR(A)/IV '23-24

A. GENERAL INFORMATION ABOUT STACK PROVIDED BY THE INDUSTRY

Stack Attached to	: D. G. - 82.5 KVA (Acoustic Enclosure attached)	Height of Stack (mtr.) (from G. L.)	: 6.0
Shape of Stack	: Circular	Stack I.D. at sampling point (mtr.)	: 0.762
Materials of Construction	: M.S.	Height of sampling port (mtr.) (from G.L.)	: Final Exhaust
Capacity	: 82.5 KVA		
Emission Due to	: Combustion of H.S.D		
Fuel Used	: H.S.D	Permanent Platform & Ladder	: No
Working Fuel Consumption	: 04 liter./hr.		
Pollution Control Device	: Nil		

B. RESULTS

SL. NO.	PARAMETERS	UNIT	METHOD NO.	RESULTS	LIMIT
1.	Flue Gas Temperature	°C	IS : 11255 (Part 1)	: 107.C	N.A.
2.	Barometric Pressure	mm of Hg.	--	: 692.C	N.A.
3.	Velocity of Gas flow	m/s	IS : 11255 (Part 3)	: 12.22	N.A.
4.	Quantity of Gas flow	Nm ³ /hr.	IS : 11255 (Part III)	: 14308.56	N.A.
5.	Concentration of SO ₂	mg/Nm ³	IS 11255 (Part 2) : 2019	: 16.46	N.A.
6.	Concentration of NO _x	mg/Nm ³	IS 11255 (Part 7) : 2017 / ASTM D 1603-93, Sec. 11 (Vol. 11.07) : 2017	: 21.52	N.A.
7.	Concentration of CO ₂	% (v/v)	IS 13270 : 2019	: 7.2	N.A.
8.	Concentration of CO	% (v/v)	IS 13270 : 2019	: <1.0	1.0
9.	Concentration of Particulate Matter	mg/Nm ³	IS 11255 (Part - 1) : 2019 & ASTM D 3685, 'D 3685M-98 (reapproved 2005) : Sec. 11 (Vol.11.07) : 2017	: 13.51	150.0

Remarks : Limit as per CPCB [Emission Regulation Part IV : COINDS/25/1986-87].
: N.A. means Not Available.
: During monitoring temporary ladder and platform were provided

Reviewed By:

DURBADAL CHAKRABORTY

Dy. Quality Manager

Authorised Signatory:

INDRANI BHATTACHARYA

Dy. Technical Manager, Chemical