

(THIS CERTIFICATE MUST BE HUNG UP IN THE BOILER HOUSE)
(FORM VI)
CHHATTISGARH BOILER INSPECTION DEPARTMENT
CERTIFICATE FOR THE USE OF A BOILER
(REGULATION 389)

Certificate No : 224131729732

Reference No : 2940476050

Udyam Aakanksha No. - 11503474848142

Registry No Of Boiler -CG/1056

Type Of Boiler - **cbc**

Place & Year Of Manufacture -China2012

Boiler Rating - **4051**

Maximum Continuous Evaporation(TPH) - **135**

Name Of Owner - **Shri Ganesan Kumar**

Situation Of Boiler - **Chakabura**

Enterprise Name - **ACB India ltd**

Repairs - **2023- nil**

Remark - **1. To steam under direct charge of certified BOEs and 1st class BA only. 2. To offer for steam test.**

Hydraulically Tested On - **27/10/2023**

to **130 Kg/cm²**

I hereby certify that the above described boiler is permitted by Me / The Chief Inspector under the provisions of Section 7 or 8 of the Boilers Act, No. V of 1923, to be worked at a maximum pressure of **102.9 Kg/cm²** for the period from **27/10/2023 To 26/10/2024**

The Loading of the **DSL** safety valve is not to exceed **102.9 Kg/cm²**

Fee Rs. **22000** paid on **18/10/2023**

Dated at: **30/10/2023**

Countersigned

Generated On- 30/10/2023 11:26:14



Dwarika Verma

OPEN UP BOILER FOR CLEANING
AFTER EVERY 26 WEEK(S) AND KEEP RECORD

Inspector Of Boilers

This is computer generated certificate and does not require seal and signature. This certificate can be verified online at <http://cg.nic.in/boiler> through Ref No. and Certificate No.