

**(THIS CERTIFICATE MUST BE HUNG UP IN THE BOILER HOUSE)**  
**(FORM VI)**  
**CHHATTISGARH BOILER INSPECTION DEPARTMENT**  
**CERTIFICATE FOR THE USE OF A BOILER**  
**(REGULATION 389)**

Certificate No : 224131729461

Reference No : 3668185440

Udyam Aakanksha No. - 11500588279572

Registry No Of Boiler -CG/160

Type Of Boiler - fbc

Place & Year Of Manufacture -PERAMANGALUM2006

Boiler Rating - 5665

Maximum Continuous Evaporation(TPH) - 125

Name Of Owner - Shri Ganesa Reddy

Situation Of Boiler - Chakabura

Enterprise Name - ACB India ltd

Repairs - 2023- nil

Remark - 1. To steam under direct charge of certified BOEs and 1st class BA only. 2. To offer for steam test.

Hydraulically Tested On - 23/09/2022

to 130 Kg/cm<sup>2</sup>

I hereby certify that the above described boiler is permitted by Me / The Chief Inspector under the provisions of Section 7 or 8 of the Boilers Act, No. V of 1923, to be worked at a maximum pressure of 103 Kg/cm<sup>2</sup> for the period from 21/09/2023 To 20/09/2024

The Loading of the DSL safety valve is not to exceed 103 Kg/cm<sup>2</sup>

Fee Rs. 26000 paid on 12/09/2023

Dated at: 22/09/2023

Countersigned

Generated On- 22/09/2023 16:31:57



Dwarika Verma

OPEN UP BOILER FOR CLEANING  
AFTER EVERY 24 WEEK(S) AND KEEP RECORD

*Inspector Of Boilers*

This is computer generated certificate and does not require seal and signature. This certificate can be verified online at <http://cg.nic.in/boiler> through Ref No. and Certificate No.