



HDD-272, PHASE III- NEAR JP CHOWK,
RING ROAD NO - 2, KABIR NAGAR, RAIPUR, C.G. -492099
PH - 0771 - 4027777 | email - ultimatenviro@gmail.com

Name & Address Of The Customer ACB (INDIA) LIMITED, 30 MW CHAKABURA POWER PLANT, P.O.- JAWALI TEHSIL - KATGHORA DIST- KORBA (C.G.) 495445		REPORT NO	UES/TR/23-24/COA/0392	
		LAB REF NO	UES/23-24/COA/074	
		DATE OF SAMPLING	16/10/2023	
		DATE OF RECEIPT	17/10/2023	
		DATE OF REPORT	21/10/2023	
		DATE OF ANALYSIS	START: 17/10/2023	END: 21/10/2023
CUSTOMER SAMPLE ID/ SAMPLING LOCATION	WASHERY REJECTED COAL	CUSTOMER REF. NO. & DATE	ACBIL/30MW/WTP/WORK- ORDER/COAL ANALYSIS/22-23/249, DATED:19.12.2022	
SAMPLE TYPE	COAL	SAMPLE CONDITION AT RECEIPT	OK	
PACKING OF SAMPLE	PLASTIC BAG	SAMPLE COLLECTED BY	LABORATORY CHEMIST	
OTHER DETAILS	SEALED	QUANTITY RECEIVED	5 KG.	

TEST REPORT

SR. NO.	PARAMETER	UNIT	METHOD OF TEST	RESULT
1	Carbon	%	ASTM D-5373-08	25.52
2	Hydrogen	%	ASTM D-5373-08	2.89
3	Nitrogen	%	ASTM D-5373-08	0.70
4	Sulphur	%	ASTM D-5373-08	0.30
5	Oxygen	%	ASTM D-3176-09	10.05

Note: Kcal/Kg: Kilo Calorie per kilo gram.

* : These parameter are not in scope approved by NABL.

REMARKS: RESULTS ARE AS ABOVE

Terms & conditions

- The report for publication, arbitration or as legal dispute is forbidden.
- Test sample will be retained for 15 days after issue of test report unless otherwise agreed with customer.
- This is for information as the party has asked for above test(s) only

 REVIEWED BY		For ULTIMATE ENVIROLYTICAL SOLUTIONS  AUTHORIZED SIGNATORY
-----------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------

-----End of the test report-----