

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/Hotel/2023/SZ/ 14

Dated: 30/05/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s The Grand Hotel, Plot No.2, Nelson Mandela Road, Vasant Kunj, New Delhi-110070 comprised of two tiers Basement, Ground floor and 05 Upper floors was issued FSC by this department vide letter No. F6/DFS/MS/Hotel/SZ/2020/227 dated 26/06/2020. The premises was re- inspected by the officer concerned of this department on 22/05/2023 in the presence of Mr. Surender Sharma and found that the said Hotel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Group A, Sub division A-5 (Hotel Building)" with effect from 30/05/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on... 30/05/2023 at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police (Lic/Branch), First Floor, P.S. Defence Colony, New Delhi-110049 (Ref. MHA Portal ID 2023042207137 dated 22/04/2023)
2. The Dy. Health Officer (MCD) Public Health Department, Green Park Zone New Delhi 110016

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
8. This FSC is valid only for Hotel. Discotheque and Restaurant will take the separate FSC, which are run by other than hotel.