

GOVERNEMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
LABOUR DEPARTMENT  
OFFICE OF THE ELECTRICAL INSPECTOR  
5, SHAM NATH MARG, DELHI - 110054

No ED 5 (905)/2012/ 7900

Dated : 09/10/2012

To,

M/s. Aria Hotels and Consultancy Services Private Limited,  
E-Basement, Clarion Collection- The Qutab Hotel,  
Shaheed Jeet Singh Marg,  
New Delhi-110016.

Sub: Inspection of the electrical installation of Sub-Station comprising of four nos. air cooled Transformers of capacity 1600 KVA , 11/0.433 KV each, one no. 11 KV five panel board ( having five nos. VCBs) & five nos. 11KV XLPE cables installed in the premises of J.W Marriot Hotel, Asset Area-4, Hospitality District, near Indira Gandhi International Airport, New Delhi-110037.

Sir,

With reference to your letter No. Aria-JWMH/INSP/01 dated 26/09/2012, the inspection of the electrical installation of Sub-Station comprising of four nos. air cooled Transformers of capacity 1600 KVA , 11/0.433 KV each, one no. 11 KV five panel board ( having five nos. VCBs) & five nos. 11KV XLPE cables installed in the premises of J.W Marriot Hotel, Asset Area-4, Hospitality District, near Indira Gandhi International Airport, New Delhi (Particulars given as under) was carried out by the undersigned on 08/10/2012. It is to inform you that at the time of inspection, the said installation has been found in order and as per provisions of the Central Electricity Authority (Measures relating to Safety & Electric Supply) Regulations, 2010.

There is no objection, so far as this office is concerned, if the said installation is brought into use.

DETAILS OF THE INSTALLATION :

I	Transformer(Air Cooled) -	4 Nos.
	Capacity	- 1600 KVA each
	Voltage Ratio	- 11000/ 433 volts each
	Make	- Kirloskar each
	Serial No.	-
		(i) 10CND110/1 .....Tr. No.1
		(i) 10CND110/2 ..... Tr. No.2
		(ii) 10CND110/3 .....Tr. No.3
		(iii) 10CND110/4 .....Tr. No.4



P.T.O.

II 11 KV five panel board ( having five nos. VCBs)- 01 No.

Rated Current - 630 Amps each  
Rated Voltage - 12 KV each  
Make - ABB each  
Serial No. - (i) IVYN020311002197 ..... Incomer  
(ii) IVYN020311002200 ..... O/G to Tr. No. 1  
(iii) IVYN020311002199 ..... O/G to Tr. No. 2  
(iv) IVYN020311002201 ..... O/G to Tr. No. 3  
(v) IVYN020311002198 ..... O/G to Tr. No. 4


III 11 KV XLPE CABLE OF SIZE 3 x 300 Sq. mm - 1 No.

LENGTH 76 Meters  
ROUTE From BSES-RPL Metering cubicle to VCB  
S.No. IVYN020311002197 (Incomer)

IV 11 KV XLPE CABLES OF SIZE 3 x 240 Sq. mm - 4 Nos.

- (a) LENGTH 14 Meters  
ROUTE From VCB S.No. IVYN020311002200 to Transformer No. 1  
(S. No. 10CND110/1 )
- (b) LENGTH 17 Meters  
ROUTE From VCB S.No. IVYN020311002199 to Transformer No. 2  
(S. No. 10CND110/2 )
- (c) LENGTH 21 Meters  
ROUTE From VCB S.No. IVYN020311002201 to Transformer No. 3  
(S. No. 10CND110/3 )
- (d) LENGTH 26 Meters  
ROUTE From VCB S.No. IVYN020311002198 to Transformer No. 4  
(S. No. 10CND110/4 )

Yours Faithfully,



(MUKESH GUPTA)  
Dy. Electrical Inspector



(MUKESH KR. SHARMA)  
Asstt. Electrical Inspector  
(Notified as Electrical Inspector Under  
Section 162 of the Electricity Act, 2003)