



HARYANA VIDYUT PRASARAN NIGAM LTD.

Regd. Office:- Shakti Bhawan, Sector-6, Panchkula
Corporate Identity Number: U40101HR1997SGC033683
Website: www.hvprn.org.in E-mail: setsrtk@hvprn.org.in
Superintending Engineer / Transmission System Circle,
132 KV Sub Station, IMT HSIIDC, Rohtak - 124001.

To

The SE / Operation Circle,
UHBVNL, Sonipat.

Through e-mail

Memo No.: -Ch-277 / TCW-123

Dated: - 05.04.2023

Sub:-


Electrification plan of Residential Plotted colony being developed over an area of 5.95625 acres by M/s Gemini Agroforms Pvt. Ltd. in the revenue estate of village Rathdhana, Sector-33 Sonipat against License No. 181 of 2022 under Operation Sub Division, UHBVNL, Model Town, Sonipat under DDJAY affordable scheme for ultimate load of 658.74 KW / 731.93 KVA proposed to be fed through 11 KV Supermax independent feeder presently being fed from 132/11 KV, 16/20 MVA T/F T-6 at 220 KV S/Stn, HVPNL, Sonipat. - Concurrence thereof.

Please refer to your office Memo No. Ch-02/DRG-234 dated 03.04.2023 vide which a memorandum for approval of Electrification plan of Residential Plotted colony being developed over an area of 5.95625 acres by M/s Gemini Agroforms Pvt. Ltd. in the revenue estate of village Rathdhana, Sector-33 Sonipat against License No. 181 of 2022 under Operation Sub Division, UHBVNL, Model Town, Sonipat under DDJAY affordable scheme for ultimate load of 658.74 KW / 731.93 KVA proposed to be fed through 11 KV Supermax independent feeder presently being fed from 132/11 KV, 16/20 MVA T/F T-6 at 220 KV S/Stn, HVPNL, Sonipat has been sent and it has been requested to give concurrence.

In the memorandum it has been intimated that the developer has requested for interim partial load requirement of 120 KW through 11 KV Supermax independent feeder presently being fed from 132/11 KV, 16/20 MVA T/F T-6 at 220 KV S/Stn, HVPNL, Sonipat. It has further been intimated that in case of overloading at 220 KV S/Stn Sonipat, if their load shall be shifted at nearby proposed 33 KV S/Stn Fazilpur-II (FY 2028-29) as per loading condition at that time. The cost for shifting of 11 KV Supermax feeder to proposed 33 KV S/Stn Fazilpur-II (2028-29) shall be borne by the developer i.e. M/s Gemini Agroforms Pvt. Ltd.

Keeping in view the above, electrification plan of Residential Plotted colony being developed over an area of 5.95625 acres by M/s Gemini Agroforms Pvt. Ltd. in the revenue estate of village Rathdhana, Sector-33 Sonipat against License No. 181 of 2022 under Operation Sub Division, UHBVNL, Model Town, Sonipat under DDJAY affordable scheme for ultimate load of 658.74 KW / 731.93 KVA proposed to be fed through 11 KV Supermax independent feeder presently being fed from 132/11 KV, 16/20 MVA T/F T-6 at 220 KV S/Stn, HVPNL, Sonipat can be considered for approval as the same has been found feasible please.

This is for your kind information and further necessary action please.


SE / TS Circle,
HVPNL, Rohtak

CC to:-

1. XEN / TS Division, HVPNL, Panipat.
2. SSE / 220 KV S/Stn, HVPNL, Sonipat.