

# OFFICE OF THE CHIEF ELECTRICAL INSPECTOR

Office of the Chief Electrical Inspector Udyog Bhavan, 6th Floor, Block No.18, Sector-11, Gandhinagar.

No/CEI/Gan/Certi/71062/2022

E-mail :  
cei-epd@gujarat.gov.in

ph no : (079) 23256642 to 44

Date : 22/6/2022

fax no : (079) 232 566 51

To  
ANJAR TMT STEEL PRIVATE LIMITED  
Welspun city  
Village-Varsamedi, Anjar  
Vi.Varsamedi  
Ta.Anjar  
Dist.Kachchh, 370110

**Subject** Initial inspection for the electrical installation of 2 x 2500.0 KVA 33/0.433 KV + 1 x 5600.0 KVA 33/0.595 KV + 3 x 4500.0 KVA 33/0.720 KV Transformer(s) & 6 x 1250.00 AMP 36.0 KV HT Breaker(s) & 9 x 33 KV Feeder bay at Anjar TMT Switchgear room along with associated equipments for I/C and O/G indoor VCB Feeders along with associated equipments at ANJAR TMT STEEL PRIVATE LIMITED, Welspun city, Village-Varsamedi, Anjar, Vi.Varsamedi, Ta.Anjar, Dist.Kachchh, Gujarat, 370110.

Sir,

Initial Inspection of the Electrical Installation of 2 x 2500.0 KVA 33/0.433 KV + 1 x 5600.0 KVA 33/0.595 KV + 3 x 4500.0 KVA 33/0.720 KV Transformer(s) & 6 x 1250.00 AMP 36.0 KV HT Breaker(s) & 9 x 33 KV Feeder bay at Anjar TMT Switchgear room along with associated equipments for I/C and O/G indoor VCB Feeders at Welspun city, Village-Varsamedi, Anjar, Vi.Varsamedi, Anjar, Kachchh, Gujarat, 370110 for ANJAR TMT STEEL PRIVATE LIMITED has been carried out by AEI, Kachchh on 20/06/2022 and the same is found in order in accordance with the drawing approved vide this office letter No: No/CEI/Gan/Plan/60310/2022, Date: 11/01/2022. The details of the same are as following.

## Details of Installation

Equipments	Make	Capacity	Sr. No.	Voltage level/Voltage ratio (KV)
Transformer	MEHI	5600.0 KVA	20038	33/0.595
HT Breaker	ABB	1250.00 AMP	YVYN020221005078	36.0

Transformer	Voltamp Transformer LTD	2500.0 KVA	52243/1	33/0.433
HT Breaker	ABB	1250.00 AMP	YVYN020221005075	36.0

Transformer	Voltamp Transformer Ltd	4500.0 KVA	52242/2	33/0.720
HT Breaker	ABB	1250.00 AMP	YVYN02022105074	36.0

<b>Transformer</b>	Voltamp Transformer LTD	2500.0 KVA	52243/2	33/0.433
<b>HT Breaker</b>	ABB	1250.00 AMP	YVYN020221005072	36.0

<b>Transformer</b>	Voltamp Transformer LTD	4500.0 KVA	52242/3	33/0.720
<b>HT Breaker</b>	ABB	1250.00 AMP	YVYN02022105071	36.0

<b>Transformer</b>	Voltamp Transformer LTD	4500.0 KVA	52242/1	33/0.720
<b>HT Breaker</b>	ABB	1250.00 AMP	YVYN02022105070	36.0

<b>Type of Line</b>	<b>No. of Feeder bay</b>	<b>Voltage Level in KV</b>	<b>Purpose</b>	<b>Location</b>
Feeder bay	9	33 KV	I/C and O/G indoor VCB Feeders	Anjar TMT Switchgear room

As provided under the Regulation 43 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2010 permission is hereby granted to energize the above installation along with the associated equipments.

**Your's Faithfully**

**A.B.CHAUDHARI**  
**CHIEF ELECTRICAL INSPECTOR**  
**Gandhinagar**

Copy forwarded to:

Applicant  
Deputy Chief Electrical Inspector, North Zone - Mehsana  
Executive Engineer (PGVCL)