

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/2023/ 91

Dated: 17/02/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Nursing Home, (Venkateshwar Hospital New Block) (A unit of All INDIA Society for Health Aid Education & Research) Located at Sector 18A, Phase - 2, Dwarka, New Delhi comprised of 03 Basement + Ground + 06 Upper Floors owned/occupied by **Nursing Home, (Venkateshwar Hospital)** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 14/02/2023 in presence of Sh. Sushil Kumar (AE Bldg) & Sh. Arwind Kumar (JE Bldg) and that the premises is fit for occupancy class "Institutional" Hospital Group C with effect from 17/02/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...17/02/2023... at New Delhi by.

  
(Ajul Garg)  
(Director)  
Delhi Fire Service  
dc h

Copy to: -

1. The Management, Nursing Home, (Venkateshwar Hospital New Block) (A unit of All INDIA Society for Health Aid Education & Research), Located at Sector 18A, Phase - 2, Dwarka, New Delhi.
2. The Executive Engineer (Bldg) HQ-1, MCD, 8<sup>th</sup> floor, E-1, Wing, Dr.SPM Civic, Minto Road, New Delhi-110002.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.