
 <p>II अक्षांश बिजली-वितरण निगम II</p>	<b>DAKSHIN HARYANA BIJLI VITRAN NIGAM</b>	
	(A Government of Haryana Undertaking) Office at the	
	Executive Engineer 'OP' Division, Sohna.	
	 0124-2362344  Fax No. 0124-2362344	
e-mail <a href="mailto:xensohnadhbvn@gmail.com">xensohnadhbvn@gmail.com</a>		

Memo No. 618

Dated: 6/5/24

To,

The SDO OP S/Division  
DHBVN, Badshahpur

**Subject :-** Sanction of load 250 KW with 278 KVA of M/s TARC Ltd Sector-63/A Gurugram applied vide A&A no. G22-324-802 dated 30.04.2024 for HT/NDS/Temp category supply.

**Reference** your office memo no. 373 dated 30.04.2024

Sanction is hereby accorded for release of load 250 KW with 278 KVA of M/s TARC Ltd Sector-63/A Gurugram (against sanctioned of ultimate load 3229.84KW with CD 3588.72 KVA by Chief Delhi vide memo no. Ch-14/CE-OP/Delhi/GNN-II/EP-73 dated 03.01.2024) on 11 KV Supply pressure and on commercial tariff of supply through existing 11KV Kadarapur (Urban) feeder from T-III power T/F emanated from 66 KV S/Stn Badshahpur, as recommended vide your office memo referred above subject to fulfillment of the following condition:-

1. The MMC agreement should be executed by the applicant.
2. Apart from other provision, instruction of sales manual specifically no. 21, 102, 105 & 258 shall be applicable in this case for which action needs to be taken in first instance accordingly.
3. All other formalities as required as per instruction issued /adopted by Nigam time to time shall be completed.
4. Metering equipments including CTs of matching capacity as per specifications / design of nigam shall be provided and meter room indicated on the sketch shall be provided at the main entrance gate of the premises as per instructions issued vide S.C No. D-11/2005 dated 13.07.2005.
5. No. applicant senior to the instant applicant /consumer is waiting sanction of load / extension of load.
6. Full advance consumption deposit and other applicable charges be recovered from the applicant before further processing the case as per S/c no. D-26/2011 & D-15/2017.
7. Full advance consumption deposit and other applicable charges be recovered from the applicant before further processing the case as per S/C No.D-12/2020 dated 25.06.2020.
8. All the documents required to be submitted by the applicant is support of proof of ownership / legal occupation of the premises, proof of identify and other documents, prescribed under sale circular no. D-40/2016, are complete and dully verified in addition to the verification vide sale circular no. D-29/2013 dated 25.06.2013.
9. The consumer will be submitted documentary proof in support of ownership of land.
10. Non - Judicial stamp worth Rs. 3/- on the left hand corner of A&A. The same shall be got affixed by the SDO before taking further action.

11. Necessary clearance certificate from various Govt. Department i.e. CEI Pollution Control Board, Huda etc shall be taken.
12. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
13. The sanctioned load is required to be built-up , within six months form the release of this connection in terms if SMI No. 1.21 and consumer should give undertaking to this effect . IF the consumer does not avail the full revised sanctioned load within above period of six months then the revised A&A forms for the availed load verified and accepted on the basis of test report may be sent to this office /competent authorities for acceptance / sanction.
14. Regarding share cost of main sub-Station , colonizer shall comply with the formalities as per instruction of the nigam issued by GM/Commercial DHBVN, Hisar .
15. Since HT broacher contains old instructions an additional affidavit shall be obtained from the consumer to abide by the provision of the electricity Act. 2003 and instruction issued by the Nigam there upon from time to time .
16. The compliance of the Sale Circular No. D-9/2013, D-72/2013, D-4/2016, & D-40/2016 & Sale Circular No. D-11/2020 dated 23.06.2020 & Sale Circular No D-21/2020 dated 07.09.2020 may be got made before release of connection.
17. All general and miscellaneous charges payable against the application in accordance with the regulation no. HERC/34/2016 dated 11.06.2016 (Duty to supply electricity on power request power to recover expenditure incurred and power to require security) circulated, circular no. D-23/2016 dt 30.08.2016 and also in accordance with sale circular no. D-29/2016 dated 12.09.2016 are fully recovered.
18. All the provision as contained in the HERC Regulation no. HERC/29/2014, (2<sup>nd</sup> the amendment) dated 8<sup>th</sup> January 2020 (Electricity supply code 2014) circulated vide sales circular no. D-07/2020 dated 28.03.2020 and amendments thereof are fully complied with and are strictly adhered to.
19. Development of electrical infra is as per technical estimate to be prepared in line with the planning & design and technical specification and construction standard of the nigam. CEA guideline & IE rule regarding safety precaution shall be adhered to for connecting the electrical system.
20. NOC may be obtained from HVPN before release of said load from 66 KV Sub-Station if required.
21. Sales manual instruction, instructions and sale circulars invoke as well as issued /amended form time to time will be applicable to the applicant the compliance of sales instructions 16/2007 read in conjunction with sales instruction No. 30/2006.
22. The erection of 11 KV Independent feeders at the consumer cost as per Nigam Specification /instructions.
23. The compliance of Instruction issued time to time which are not incorporate in the above are required to be complied with by the consumer .
24. The consumer will deposit full ACD as per sales circular no. D-12/2020 for the entire load including security for HT tri-vector meter if the same is not supplied by the consumer.
25. The location of metering equipment should be near the main entrance gate for free accessibility and its site will be decided in advance marked on the sketch by concerned SDO.
26. All instruction of sales manual amended from time to time shall be applicable.
27. Completion of requisite formalities as per Sales Circular no. D-26/2011 dated 09.09.2009.



28. Technical load has been sanctioned prejudice to the fulfillment of preliminary mandatory requirement of applying the connection of a premises i.e. proof of ownership, tenancy, lease deed, registry, layout plan etc.
29. Application for temporary connection at the project site of the colonizer / developer shall only be allowed, if it is submitted along with the approved electrification plan. Where the electrification plan has been submitted for approval, the application for temporary connection shall only be considered when all the valid documents i.e. License, layout plan, undertakings have been submitted and there is no deficiency on the part of the applicant and the approval is pending on part of the Nigam for finalization of electrification plan and technical feasibility. Concerned SE (OP) shall ensure that the pending electrification plan is approved within one month by following up with various officers.
30. Prior to the release of partial load, necessary compliance requirements towards the submission of an irrevocable BG's by the applicant to Nigam is duly completed in view of the sales circular no. D-52/2017 dated 22.12.2017 and sales circular no. D-28/2018 issued by Nigam.
31. Latest Nigam sales circular no. D-9/2013, D-72/2013, D-4/2016, & D-40/2016 & Sale Circular No. D-11/2020 dated 23.06.2020 & Sale Circular No D-21/2020 dated 07.09.2020 & Sales circular no. 23/2020 and all other applicable instructions. You are hereby advise to make the necessary compliances of all the applicable instruction may be followed meticulously of Nigam in the instant case before release of this connection.
32. Some load of Kadarpur feeder was shift on 11 KV Pioneer feeder.

  
XEN OF Division  
DHBVN SOHNA

CC to :-

**M/s TARC Ltd Sector-63/A Gurugram** This load sanction shall be contingent upon the compliances of the statutory requirements from you as per the instructions/ regulations of Nigam stipulated above. However it is also being made clear that sanction of extension of load has been approval as per the applicable regulations and instructions of the Nigam in view of the A&A form and other documents and details furnished by you. For any misrepresentation of the information & facts by you, this approval shall deemed to be cancelled and if any of the information & fact found / noticed to be fabricated and mislead at any stage, which may otherwise lead to explicit or implicit loss of Nigam, you shall be liable to make good such loss to Nigam. This shall however be without prejudice to the rights of Nigam to take recourse in the matter as per the legal remedies available with the Nigam.

For any further references to the instructions / regulations of the Nigam mentioned in this communication, you may visit [www.dhbvn.org.in](http://www.dhbvn.org.in)