

## GST NO. 09AYLPV4104F1Z9

Distributor of Dessert Board • Plywood • Laminate • MDF • HDHMR • Flush Door • Shuttering Ply etc.
All Interior Solution



+91-8076428096 - +91-9311263646



studiocharcoal20@gmail.com

**1** 

C-34, Sector 4, Noida(GBN), U.P., 201301

A Vendo

Date : Date : Care

Rajasthan State Industrial Development

&Investment Corporation Ltd.

Ghiloth (Camp Shahjahanpur)

Dist. Kotpuli- Behror (Rajasthan)

SUB: In the matter of approval of Building, Plot No. SP5-172, Industrial Area, Ghiloth (Kotpuli-Behror)

Dear Sir,

With reference to above cited subject, it is to inform you that the following discrepancies have been rectified in the drawings submitted to you –

- 1. Height of mumty has been reduced.
- 2. Ramp is proposed inside the plot.
- 3. Parking and calculation have been mentioned.
- 4. Setback facilities have been rectified.
- 5. Distance of setback line is mentioned.
- b. North and Scale is mentioned.

Three copies of building plans have been submitted.

Thank you

Ar. Aful Vasisht

Principal Architect Studio Charcoal ATU VASICHT









## Rajasthan State Industrial Development & Investment Corporation Ltd.

( A Rajasthan Government Undertaking)
Ghiloth (Camp Shahjahanpur), Dist. Kotputli-Behror(Raj.)-301:
Contact No.:01494-236011 e-mail: ghiloth@riico.co.in

(Regd. Ad.)

S.No.: RM/GHT/2024-25/1581

Date: 17/10/2024

M/S SSRM GLASSES PVT. LTD., A-196,SECTOR-20, Noida Gautam Budh Nagar, Uttar Pradesh-201301

Subject: In the matter of approval of Building plan, Plot No. SP5-172, Industrial Area, Ghiloth (Kotputli-Behror).

Dear Sir,

With reference to above cited subject, it is to inform you that the following are the discrepancies in the building plan submitted by you:-

- 1. Height of mumty is more than permissible.
- 2. Ramp is proposed outside of plot.
- 3. There is no parking and parking calculation is mentioned in drawing.
- 4. Setback facilities is not as per building regulation.
- 5. Distance of setback line is not mentioned.
- 6. North point and scale of drawing is not mentioned.

Hence you are directed to submit 3 copy of revised building plans as per above mentioned details. So, that further action may be taken on your request

Thanking you

Unit Head RIICO Ghiloth

Signature Not Verified

Digitally signed by Syed Ibney

Designation : Regional Manager Date: 2024.10.17 17:14:22 IST

Reason: Approved

