



**Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16**

Memo no.:IND/WB/FES/20192020/73700

Date: 20-12-2022

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Narayana Multispeciality Hospital (Unit of Narayana Hrudayalaya Ltd)
78 Jessore Road (South), Barasat, North 24Pgs, Pin- 700127

Sub: Renewal of Fire Safety Certificate for the existing G+V storied Institutional Building named as "Narayana Multispeciality Hospital" (A Unit Of Narayana Hrudayalaya Ltd.) at the Premises No. 78 Jessore Road South , Barasat, North 24Pgs, Pin- 700127.

This is in reference to your application no. 0125191221100771 dated 01-11-2022 regarding the Renewal of Fire Safety Certificate for the existing G+V storied Institutional Building named as "Narayana Multispeciality Hospital" (A Unit Of Narayana Hrudayalaya Ltd.) at the Premises No. 78 Jessore Road South , Barasat, North 24Pgs, Pin- 700127.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- The Interior finish decoration of building shall be made with low flame spread material conforming I.S. specification.
2. To eliminate risk of Fire Hazard, good house keeping both for inside and outside of the building shall be strictly maintained.
 5. Electrical wiring of the whole building shall have to be carefully checked for any wear & tear in them, particularly lines above falls ceiling and duct.
 6. The notice of Fire Fighting, Floor nos. and evacuation from the building shall be displayed at all vulnerable places of the building.
 7. A Fire control room including a C.C.T.V. system to be maintained always which will observe all the floor of the building.
 8. The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the building and to

operate in the event of Fire & Testing.

9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

10. Transformer, Switch Gear room always to be protected with automatic Gas based suppression system, Water spray projector system conforming I.S. specification.

11. First Aid Fire Fighting system shall be maintained as per I.S. specification.

12. Electrical ducts always to be kept in sealed condition with fire resisting materials.

13. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent percolation of smoke.

14. The management of the organization / building as the case may be shall maintain the fire prevention & safety measures in good repair and in efficient condition at all times which are installed in the said building for use at the time of fire or other emergencies.

15. Periodical flashing of water from the hydrants & sprinkler pipe line shall be made to maintain the efficient working performance of above mentioned system.

16. The fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

17. Fire pumps always to be kept in auto mode condition.

18. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.

19. Gas cylinders to be stored / used as per guideline of Gas Cylinder Rule, 2004 as amended upto date.

20. Gas pipe installations to be as per Part 9 'Plumbing Services, Section 4 Gas Supply' of the N.B.C. - 2016.

21. Flammable gas cylinders must be separated from oxygen cylinders by a distance of 6m or by a wall of 30 minutes fire resistance. Empty cylinders must be marked /tagged and stored separately.

22. Gas detectors must be installed for detecting gas leaks.

23. Fire suppression system to be provided for gas bank area as I.S. Specification.

24. Bulk storage of flammable materials such as chloroform, ethyl alcohol, spirit etc. will be governed by relevant rules and safe practices.

25. Lightning protection for building shall be provided as per Part 8 'Building Services', Section 2 Electrical installations of N.B.C - 2016.

This Fire Safety Certificate is valid for three year and have to be renewed within the validity limit from the date of issue of this letter, performance of all the Fire safety arrangements and installations of the building.

Divisional Fire Officer
West Bengal Fire & Emergency Services