



U.T. Administration of Dadra & Nagar Haveli and Daman
& Diu,
Department of Fire & Emergency Services,
Fire Force Headquarters, Daman,
Daman-396215.
E-Mail ID: sfo-dmn-dd@nic.in.



No.DFES/DMN/AREN-NOC/867/ADFO/2023

Application ID. NOC/R202324/01687

Dated:- 28-10-2023.

To,
M/s. FIBERWEB (INDIA) LIMITED,
Survey No. 92 & 93-B, KADAIYA,
COSTAL HIGHWAY, KADAIYA,
DAMAN- 396210.

Sub : RENEWAL OF FIRE NOC OF THE FACTORY BUILDING REG

- Ref: 1. Your application dated 27/08/2023.
2. No. 50/49/IND/2021-22/DMNFES/51 dated 22/02/2022.
3. Fire Safety Inspection report dated 05/09/2023.

Sir,

Kindly refer to your application vide dated 27/08/2023 on the subject cited above, and to kindly inform that you have applied for Renewal of fire NOC of the factory building having ground + 2nd upper floors with total height **16.00 meters** from the general ground level up to the terrace level on land bearing Sr. No. 92, 93-B, Village Kadaiya, Nani Daman.

The said factory building plan is approved by the competent authority as submitted by the applicant. The details of construction and plot area are shown in the approved plan of the buildings which are as under:

Sr. No.	Particulars of Construction	Total B/U area (Sq. M.)
01.	Total area of the plot	17627.50
	Permissible Gr. cov. @ 40%	7051.00
	Consumed Gr. cov. @ 27.07%	4773.42
	Permissible FAR/FSI @ 1	17627.50
	Consumed FSI @ 0.367	6477.61
02.	Proposed built up area	
	Ground floor	4773.42
	First floor	1548.29
	Second Floor	155.90
	TOTAL BUILT UP AREA	6477.61
03.	Total height of building	16 .00
04.	No. and width of staircases	01/1.30
05.	Total Distance from Fire Station to factory building in Kms.	8.4 Km.
06.	Manufacturing of Spun Bond Nonwoven Fabric	

The site abuts have Coastal Highway about 25 meters wide on West side as shown on the plans of the building. Open space around the main factory buildings from plot boundary is as shown below:

Sides	Open spaces as per approved plan	Open spaces physically measured during the inspection on 05.09.2023.	Width of abuts road
North	08.00 Meters	11.50 Meters	+ 25 meters wide road.
South	08.00 Meters	37.60 Meters	--
East	08.00 Meters	24.50 Meters	--

West	08.00 Meters	13.00 Meters	--
------	--------------	--------------	----

The above said premise was inspected by **Concern Officers** on **05/09/2023** in the presence of **Shri Bhaskaray N. Raval** and found that the fire fighting system are satisfactory working condition at the time of inspection.

In view of the above, so far as department is concerned, there is no objection from the fire safety point of view for renewal of Fire No-Objection Certificate for further period of one year of the factory building having Ground floor + Mezzanine floor with total height of **16.74** meters from the general ground level up to the roof/terrace level on land bearing Survey No. 92, 93/B, Coastal Highway, village Kadaiya, Nani Daman for Manufacturing of Spunbond Nonwoven Fabrics as required under the Notification No.DFS/DD/F.P.-Notification/2004-05/627 dated 12-01-2005 issued under sub-section (1) of section 13 of the Goa, Daman and Diu Fire Force Act, 1986 subject to compliance of the following condition.

1. All the fire safety arrangements provided therein shall be maintained periodically and in good working condition at all times. If the said system is not maintained, retrenched, this N.O.C. will stand cancelled without any notice and you will be fully responsible to loss of life or property, if any, which may please be noted.
2. Courtyard all around the building should be always free from obstruction and encroachment for fire brigade access.
3. The storage, use and handling gasoline, fuel oil, explosive materials and other flammable liquid/gas shall not be permitted in any Group G occupancy unless it complies with the regulations and in the event of any violation; the (Owner/Occupier) of the said premises will be liable to be dealt with penal action.
4. No residential accommodation as well as kitchen should be provided in the industrial building in any circumstances.
5. The trained fire fighting staff should be available round the clock.
6. Any compartmentation in addition to the approved plan shall be made only prior approval of the fire department.
7. This fire NOC is issued in fire prevention and life safety point only, the legality of land/plot, any deviation with respect to construction etc. shall be verified confirmed by the concerned building plan sanctioning authority.
8. This fire NOC may not treated in any case for regularization of unauthorized construction, if any.
9. No change purpose of occupancies or title of the building other than approved plan without prior approval of the Fire department.
10. The eliminate fire hazards, good housekeeping both inside and outside the building shall be strictly maintained by the owner or occupier of the Factory building.
11. It shall be sole responsibility/duty of Management/Owner/Occupant of the Factory building to conduct safe evacuation drill/fire fighting drill periodically in the event of fire and other emergency.
12. The applicant shall required to be obtained annual renewal of fire NOC from the fire department before applying for renew of factory license.
13. The applicant shall be required to submit the proposal to obtain annual renewal of Fire No Objection Certificate before **Two month** from the date expired fire NOC i.e.

21/02/2025.

14. It shall also be sole responsibility/duty of Management/Owner/Occupier of the Factory building to maintain the entire arrangement of fire fighting system and equipments/accessories installed in the Factory building in good working condition so as to ensure their perfect serviceability at all times.
15. The competent authority reserves right to amend any additional recommendations deemed fit during final inspection or in future due to the statutory provisions amended from time to time and in the interest of the protection of the company and employees.
16. Right to reject/withdrawn N.O.C. at any time without any notice is vested /reserved with the competent authority if the conditions stipulated above are not complied with.
17. This is issued for a period of two year from the period i.e. **22/02/2023 to 21/02/2024 and 22/02/2024 to 21/02/2025** and subject renewed from time to time failing which the same should be cancelled.

On breach of any of the above conditions, the department shall take punitive/penal action as per Notification No.DFS/DD/F.P.-Notification/2004-05/627 dated 12-01-2005 issued under sub-section (2) of section 13 of the Goa, Daman & Diu Fire Force Act, 1986 subject to compliance of the above conditions.

The applicant has paid the renewal fees to the tune of Rs. 5000/- (Rupees Five Thousand Only) by Bank Challan Quotation No. 1580454465612 dated 19/10/2023.

Your Faithfully



**Assistant Director,
Fire & Emergency Services,
DNH and Daman & Diu,
Daman.**

Copy to:

1. PA to DIGP/Director of Fire & Emergency Services, DNH and Daman & Diu, Daman.
2. Office copy.